

... Fire Protection by Computer Design

ALTERNATIVE SPRINKLER  
39 JACKSON RD.  
POLAND SPRING, ME  
04274  
207-838-8930

Job Name : 98 WASHINGTON AVE 4TH FL CALC  
Building : FP-01  
Location : 4TH FLOOR BED ROOM  
System : #2  
Contract :  
Data File : 98 WAHSINGTON AVE 4TH FL CALC.WXF

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** 98 WASHINGTON AVE 4TH FL CALC  
**Location:** 4TH FLOOR BED ROOM  
**Drawing no:** FP-01  
**Date:** 12-2-15

**Design**

**Remote area number:** #2  
**Remote area location:** 4TH FLOOR BEDROOM  
**Occupancy classification:** LIGHT HAZARD  
**Density:** .05 - Gpm/SqFt  
**Area of application:** 180 - SqFt  
**Coverage per sprinkler:** 256 - SqFt  
**Type of sprinklers calculated:** RELIABLE RES 44 HSW  
**No. of sprinklers calculated:** 4  
**In-rack demand:** - GPM  
**Hose streams:** 100 - GPM  
**Total water required (including hose streams):** 169.91 - GPM@ 79.8641 - Psi  
**Type of system:** NFPA 13 WET SYSTEM  
**Volume of dry or preaction system:** N/A - Gal

**Water supply information**

**Date:** 5-23-15  
**Location:** WASHINGTON AVE  
**Source:** PORTLAND WATER DEPT.

**Name of contractor:** ALTERNATIVE SPRINKLER  
**Address:** 39 JACKSON RD. / POLAND SPRING, ME / 04274  
**Phone number:** 207-838-8930  
**Name of designer:** TIM FORTIN  
**Authority having jurisdiction:** STATE OF MAINE / CITY OF PORTLAND  
**Notes:** (Include peaking information or gridded systems here.)


# Water Supply Curve (C)

ALTERNATIVE SPRINKLER  
98 WASHINGTON AVE 4TH FL CALC

Page 2  
Date 12-2-15

City Water Supply:  
C1 - Static Pressure : 86  
C2 - Residual Pressure: 78  
C2 - Residual Flow : 1299

Demand:  
D1 - Elevation : 17.324  
D2 - System Flow : 69.91  
D2 - System Pressure : 79.864  
Hose ( Adj City ) :  
Hose ( Demand ) : 100  
D3 - System Demand : 169.91  
Safety Margin : 5.950



# Fittings Used Summary

ALTERNATIVE SPRINKLER  
98 WASHINGTON AVE 4TH FL CALC

Page 3  
Date 12-2-15

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zik	Wilkins 950XL	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
Length Units               Feet  
Flow Units                 US Gallons per Minute  
Pressure Units             Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

ALTERNATIVE SPRINKLER  
98 WASHINGTON AVE 4TH FL CALC

Page 4  
Date 12-2-15

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	40.0	4.4	13.3	na	16.05	0.05	256	13.3
3	40.0	4.4	13.38	na	16.1	0.05	256	13.3
2	40.0		13.86	na				
5	40.0	4.4	16.41	na	17.83	0.05	256	13.3
4	40.0		16.99	na				
6	40.0	4.4	20.54	na	19.94	0.05	256	13.3
7	40.0		21.73	na				
8	40.0		21.95	na				
9	40.0		24.45	na				
10	32.0		32.76	na				
11	32.0		35.19	na				
12	32.0		42.47	na				
13	24.0		48.55	na				
14	24.0		51.66	na				
15	24.0		54.28	na				
16	16.0		58.85	na				
17	16.0		61.47	na				
TOR	8.0		66.63	na				
BOR	8.0		73.52	na				
UG	1.0		79.43	na				
TEST	0.0		79.86	na	100.0			

The maximum velocity is 18.55 and it occurs in the pipe between nodes 4 and 8

Final Calculations - Hazen-Williams

ALTERNATIVE SPRINKLER  
98 WASHINGTON AVE 4TH FL CALC

Page 5  
Date 12-2-15

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	16.05	1.049	1T	5.0	1.500	13.300			K Factor = 4.40	
to		120.0		0.0	5.000	0.0				
2	16.05	0.0866		0.0	6.500	0.563			Vel = 5.96	
	0.0									
	16.05					13.863			K Factor = 4.31	
3	16.10	1.049	1T	5.0	0.500	13.384			K Factor = 4.40	
to		120.0		0.0	5.000	0.0				
2	16.1	0.0871		0.0	5.500	0.479			Vel = 5.98	
2	16.04	1.049	2E	4.0	6.000	13.863				
to		120.0		0.0	4.000	0.0				
4	32.14	0.3130		0.0	10.000	3.130			Vel = 11.93	
	0.0									
	32.14					16.993			K Factor = 7.80	
5	17.83	1.049	1T	5.0	0.500	16.415			K Factor = 4.40	
to		120.0		0.0	5.000	0.0				
4	17.83	0.1051		0.0	5.500	0.578			Vel = 6.62	
4	32.14	1.049	1T	5.0	2.000	16.993				
to		120.0		0.0	5.000	0.0				
8	49.97	0.7081		0.0	7.000	4.957			Vel = 18.55	
	0.0									
	49.97					21.950			K Factor = 10.67	
6	19.94	1.049	1E	2.0	7.200	20.538			K Factor = 4.40	
to		120.0		0.0	2.000	0.0				
7	19.94	0.1293		0.0	9.200	1.190			Vel = 7.40	
7	0.0	1.38	1T	6.0	0.500	21.728				
to		120.0		0.0	6.000	0.0				
8	19.94	0.0342		0.0	6.500	0.222			Vel = 4.28	
	0.0									
	19.94					21.950			K Factor = 4.26	
8	69.91	1.38	1E	3.0	4.200	21.950				
to		120.0		0.0	3.000	0.0				
9	69.91	0.3465		0.0	7.200	2.495			Vel = 15.00	
9	0.0	1.38	1T	6.0	8.000	24.445				
to		120.0		0.0	6.000	3.465				
10	69.91	0.3466		0.0	14.000	4.853			Vel = 15.00	
10	0.0	1.38	1T	6.0	1.000	32.763				
to		120.0		0.0	6.000	0.0				
11	69.91	0.3466		0.0	7.000	2.426			Vel = 15.00	
11	0.0	1.38	1T	6.0	15.000	35.189				
to		120.0		0.0	6.000	0.0				
12	69.91	0.3466		0.0	21.000	7.279			Vel = 15.00	

Final Calculations - Hazen-Williams

ALTERNATIVE SPRINKLER  
98 WASHINGTON AVE 4TH FL CALC

Page 6  
Date 12-2-15

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
12	0.0	1.61	1T 8.0	8.000	42.468				
to		120.0	0.0	8.000	3.465				
13	69.91	0.1636	0.0	16.000	2.617		Vel = 11.02		
13	0.0	1.61	1T 8.0	7.000	48.550				
to		120.0	1E 4.0	12.000	0.0				
14	69.91	0.1636	0.0	19.000	3.109		Vel = 11.02		
14	0.0	1.61	1T 8.0	8.000	51.659				
to		120.0	0.0	8.000	0.0				
15	69.91	0.1636	0.0	16.000	2.618		Vel = 11.02		
15	0.0	1.61	1E 4.0	2.800	54.277				
to		120.0	0.0	4.000	3.465				
16	69.91	0.1635	0.0	6.800	1.112		Vel = 11.02		
16	0.0	1.61	1T 8.0	8.000	58.854				
to		120.0	0.0	8.000	0.0				
17	69.91	0.1636	0.0	16.000	2.618		Vel = 11.02		
17	0.0	2.067	1T 10.0	25.000	61.472				
to		120.0	0.0	10.000	3.465				
TOR	69.91	0.0485	0.0	35.000	1.696		Vel = 6.68		
TOR	0.0	2.067	1G 1.0	7.000	66.633				
to		120.0	1Z 5.0	6.000	6.259		* Fixed loss = 6.259		
BOR	69.91	0.0484	1Zik 0.0	13.000	0.629		Vel = 6.68		
BOR	0.0	1.917	1E 3.464	30.000	73.521				
to		120.0	1T 6.929	11.086	3.032				
UG	69.91	0.0699	1G 0.693	41.086	2.873		Vel = 7.77		
UG	0.0	11.938	1E 27.0	400.000	79.426				
to		120.0	1T 60.0	87.000	0.433				
TEST	69.91	0.0	0.0	487.000	0.005		Vel = 0.20		
	100.00						Qa = 100.00		
	169.91				79.864		K Factor = 19.01		