



BASEMENT FIRE ALARM PLAN
 SCALE: 1/4"=1'-0"

NOTE:
 ELECTRICIAN WILL BE INSTALLING
 120V SMOKE/CO DETECTORS IN
 THE RESIDENTIAL UNITS

SHEET NOTES:
 ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW,
 PRESSURE SWITCHES, TAMPER SWITCHES AND POST INDICATING VALVES ASSOCIATED
 WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY
 EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY
 EXACT QUANTITY AND LOCATION(S).

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	12/18/2015

CUNNINGHAM
Security Systems
 10 Princes Point Road, Yarmouth, Maine 04096
 Office: 207.846.3350 • Fax: 207.846.6080

98 WASHINGTON AVENUE
PORTLAND, MAINE 04101
BASEMENT FIRE ALARM PLAN

DRAWN	JPB UNICAD JOB #159880
CHECKED	WAYNE B. HAWES NCEIT # 90496
DATE	12/18/2015
REVISION	0
SCALE	1/4"=1'-0"

UNICAD Inc.
 575 W. 40th St.
 Portland, ME 04102
 Office: 207.846.6110
 www.unicad.net
UNICAD
 Fire Alarm Design & Drafting Services
FA-2