



Portland Fire Department

11/19/2019

MAINE MUSLIM COMMUNITY CENTER
118 ANDERSON ST
PORTLAND, ME 04101
gouled.a.hussein@gmail.com

CERTIFIED MAIL

RE: 118 ANDERSON ST
PORTLAND, ME 04101

012 N004001

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 10/29/2019 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 12/4/2019 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
PFD Rules, 5.10.2	All signal systems must have a current inspection sticker issued by a Master Fire Alarm Company.	Sticker was from 2017.	11/12/2019
NFPA 101-4.5.8, 7.9.3	Emergency lights must be kept in good working order.	Three emergency lights not working, the bathroom, the common area, and one in the prayer room.	11/28/2019