Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/21/17

FAN#1 - EXHAUST PERFORMANCE CURVES.

800 CFM, 0.35 SP @ 1270 RPM and 0.139 BHP at 108 feet and 70 deg F
* Please note that these curves were adjusted for job specific temperature and altitude.

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted ☐
Approved with NO Exception Taken ☐
Revise and Resubmit ☐
SIGNATURE _____
Your Title _____ Date _____

CAPTIVEAIRE

JOB A&C Grocer	
LOCATION Biddeford, ME,	
DATE 3/9/2017	JOB # 2905587
DWG # 4	DRAWN BY BFC-21
REV.	SCALE 3/8" = 1'-0"