Reviewed for Code Compliance
Inspection Division
Date: 03/21/17

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 16" O.C. - EXISTING WALL

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NC	N/A	N/A		N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - 1" AIR SPACE - EXISTING WALL TO REMAIN

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NB	N/A	N/A		N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF TYPE 'X' 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 24" O.C. - 5-1/2" SOUND BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
1B	1 HR	V450		N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NA	N/A	N/A		N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF TYPE 'X' 5/8" GWB - 1/2" RESILIENT SOUND CHANNEL @ 24" O.C. - 6" LIGHT GAUGE METAL STUDS AT 24" O.C. - 5-1/2" SOUND BATT INSULATION - 1/2" HOMASOTE - LAYER OF TYPE 'X' 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
1A	1 HR	V450		N/A

WALL TYPE NOTES

1.) REFER TO STRUCTURAL DRAWINGS FOR STUD SIZE AND SPACING

2.) INSTALL WATER RESISTANT GYPSUM WALLBOARD IN ALL RESTROOMS AND TOILET ROOM WALLS AND CEILINGS, AND AT ANY WALL WITH PLUMBING FIXTURES

3.) PROVIDE ½" GWB BEHIND ALL TUBS AND SHOWERS AT EXTERIOR WALLS AND FIRE RATED ASSEMBLIES. PROVIDE ADDITIONAL LAYER OF GWB TO COVER TUB AND SHOWER FLANGE. EXTEND ADDED LAYER ALONG ADJACENT WALLS AND ADJUST DOOR JAMB WIDTHS AS REQUIRED.

4.) WHEN TWO ADJACENT WALL TYPES HAVE DIFFERING NUMBERS OF LAYERS OF GWB, THE FINISHED FACE OF GWB MUST FORM ONE CONTIUOUS PLANE, ADJUST STUD PLANE LOCATION AS REQUIRED TO ACHIEVE THE CONTINUOUS PLANE

5.) HOLD BOTTOM OF GWB UP 1/2" FROM CONCRETE, PROVIDE SEALANT AT JOINT.

6.) ALL WALL TYPES WITH AN INSULATION COMPONENT TO BE ACOUSTICALLY SEALED

7.) ALL NON LOAD BEARING WALLS THAT EXTEND UP TO DECK TO HAVE HEAD DEFLECTION SLIP TRACKS

REGISTERED ARCHITECT
RYAN J. SENATORE
No. 3322
STATE OF MAINE

© 2016 RYAN SENATORE ARCHITECTURE

123 WASHINGTON

123 WASHINGTON AVENUE
PORTLAND, MAINE

RSA
RYAN SENATORE
ARCHITECTURE
565 CONGRESS STREET
PORTLAND, MAINE 04101
207-650-6414
senatorearchitecture.com

CONSULTANTS:

REVISIONS:

DATE:	DECEMBER 05, 2016
PROJECT No.	1638
DRAWN BY:	JPF
CHECKED BY:	RJS
SCALE:	AS NOTED

SHEET TITLE:
WALL ASSEMBLIES

A0-1