



© 2017 RYAN SENATORE ARCHITECTURE

**MAINE CRAFT DISTILLING**  
 123 WASHINGTON STREET  
 PORTLAND, MAINE



RYAN SENATORE ARCHITECTURE  
 565 CONGRESS STREET  
 PORTLAND, MAINE 04101  
 207-650-6414  
 senatorearchitecture.com

CONSULTANTS:

REVISIONS:  
 ▲ REVISION #1 - 5 / 17 / 17

DATE: FEBRUARY 14, 2017

PROJECT No. 1666

DRAWN BY: RRT

CHECKED BY: RJS

SCALE: AS NOTED

SHEET TITLE:

**WALL TYPES AND ASSEMBLIES**

**A0-1**

GRAPHIC DEPICTION		DESCRIPTION											
		- LAYER OF TYPE 'X' 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 24" O.C. - 5-1/2" SOUND BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>1A</td> <td>1 HR</td> <td>V450</td> <td>50-54</td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	1A	1 HR	V450
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
1A	1 HR	V450	50-54	N/A									

GRAPHIC DEPICTION		DESCRIPTION											
		- LAYER OF 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 16" O.C. - 5-1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>NC</td> <td>N/A</td> <td>N/A</td> <td></td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	NC	N/A	N/A
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
NC	N/A	N/A		N/A									

GRAPHIC DEPICTION		DESCRIPTION											
		- LAYER OF TYPE 'X' 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 24" O.C. - 5-1/2" SOUND BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>1B</td> <td>1 HR</td> <td>V450</td> <td></td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	1B	1 HR	V450
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
1B	1 HR	V450		N/A									

GRAPHIC DEPICTION		DESCRIPTION											
		- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - 3 1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>NB</td> <td>N/A</td> <td>N/A</td> <td></td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	NB	N/A	N/A
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
NB	N/A	N/A		N/A									

GRAPHIC DEPICTION		DESCRIPTION											
		- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - LAYER OF 5/8" GWB											
		<table border="1"> <thead> <tr> <th>TYPE</th> <th>FIRE RATING</th> <th>UL NUMBER</th> <th>STC RATING</th> <th>IIC RATING</th> </tr> </thead> <tbody> <tr> <td>NA</td> <td>N/A</td> <td>N/A</td> <td></td> <td>N/A</td> </tr> </tbody> </table>				TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING	NA	N/A	N/A
TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING									
NA	N/A	N/A		N/A									

- WALL TYPE NOTES**
- 1.) REFER TO STRUCTURAL DRAWINGS FOR STUD SIZE AND SPACING
  - 2.) INSTALL WATER RESISTANT GYPSUM WALLBOARD IN ALL RESTROOMS AND TOILET ROOM WALLS AND CEILINGS, AND AT ANY WALL WITH PLUMBING FIXTURES
  - 3.) PROVIDE 1/2" GWB BEHIND ALL TUBS AND SHOWERS AT EXTERIOR WALLS AND FIRE RATED ASSEMBLIES. PROVIDE ADDITIONAL LAYER OF GWB TO COVER TUB AND SHOWER FLANGE. EXTEND ADDED LAYER ALONG ADJACENT WALLS AND ADJUST DOOR JAMB WIDTHS AS REQUIRED.
  - 4.) WHEN TWO ADJACENT WALL TYPES HAVE DIFFERING NUMBERS OF LAYERS OF GWB, THE FINISHED FACE OF GWB MUST FORM ONE CONTINUOUS PLANE. ADJUST STUD PLANE LOCATION AS REQUIRED TO ACHIEVE THE CONTINUOUS PLANE.
  - 5.) HOLD BOTTOM OF GWB UP 1/2" FROM CONCRETE, PROVIDE SEALANT AT JOINT.
  - 6.) ALL WALL TYPES WITH AN INSULATION COMPONENT TO BE ACOUSTICALLY SEALED