Reviewed for Code Compliance
Inspections Division
Portland, Maine
Date: 05/23/17

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF TYPE 'X' 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 24" O.C. - 5-1/2" SOUND BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
1A	1 HR	V450	50-54	N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 16" O.C. - 5 1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NC	N/A	N/A		N/A

1

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF TYPE 'X' 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 24" O.C. - 5-1/2" SOUND BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
1B	1 HR	V450		N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - 3 1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NB	N/A	N/A		N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NA	N/A	N/A		N/A

WALL TYPE NOTES

1.) REFER TO STRUCTURAL DRAWINGS FOR STUD SIZE AND SPACING

2.) INSTALL WATER RESISTANT GYPSUM WALLBOARD IN ALL RESTROOMS AND TOILET ROOM WALLS AND CEILINGS, AND AT ANY WALL WITH PLUMBING FIXTURES

3.) PROVIDE ½" GWB BEHIND ALL TUBS AND SHOWERS AT EXTERIOR WALLS AND FIRE RATED ASSEMBLIES. PROVIDE ADDITIONAL LAYER OF GWB TO COVER TUB AND SHOWER FLANGE. EXTEND ADDED LAYER ALONG ADJACENT WALLS AND ADJUST DOOR JAMB WIDTHS AS REQUIRED.

4.) WHEN TWO ADJACENT WALL TYPES HAVE DIFFERING NUMBERS OF LAYERS OF GWB, THE FINISHED FACE OF GWB MUST FORM ONE CONTIUOUS PLANE, ADJUST STUD PLANE LOCATION AS REQUIRED TO ACHIEVE THE CONTINUOUS PLANE

5.) HOLD BOTTOM OF GWB UP 1/2" FROM CONCRETE, PROVIDE SEALANT AT JOINT.

6.) ALL WALL TYPES WITH AN INSULATION COMPONENT TO BE ACOUSTICALLY SEALED

REGISTERED ARCHITECT
RYAN J. SENATORE
No. 3322
STATE OF MAINE

© 2017 RYAN SENATORE ARCHITECTURE

MAINE CRAFT DISTILLING

123 WASHINGTON STREET
PORTLAND, MAINE

RSA
RYAN SENATORE
ARCHITECTURE
565 CONGRESS STREET
PORTLAND, MAINE 04101
207-650-6414
senatorearchitecture.com

CONSULTANTS:

REVISIONS:
1 REVISION #1 - 5 / 17 / 17

DATE: FEBRUARY 14, 2017
PROJECT No. 1666
DRAWN BY: RRT
CHECKED BY: RJS
SCALE: AS NOTED

SHEET TITLE:
WALL TYPES AND ASSEMBLIES

A0-1