



... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Rd
PO Box 156
Poland, ME, 04274
207-998-2551

Job Name : 123 Washington Ave Restaurant Area
Building : 1
Location : Restaurant
System : 1
Contract : 061417-1
Data File : Restaurant.WXF

HYDRAULIC CALCULATIONS
for

Project name: 123 Washington Ave Restaurant Area
Location: Restaurant
Drawing no: 1
Date: 4/6/2017

Design

Remote area number: 1
Remote area location: 1
Occupancy classification: Light Hazard
Density: .10 - Gpm/SqFt
Area of application: 950 - SqFt
Coverage per sprinkler: 196 - SqFt
Type of sprinklers calculated: Commercial Uprights
No. of sprinklers calculated: 9
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 298.834 - GPM @ 61.7652 - Psi
Type of system: NFPA 13 wet
Volume of dry or preaction system: - Gal

Water supply information

Date: 08/25/2016
Location: Corner of Fox Street and Washington Ave
Source: Portland Water District

Name of contractor: High Tech Fire Protection
Address: 84 Hackett Mills Rd / PO Box 156 / Poland, ME, 04274
Phone number: 207-998-2551
Name of designer: Ed Pennell
Authority having jurisdiction: Portland Fire Department
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve (C)

High Tech Fire Protection
123 Washington Ave Restaurant Area


Page 2
Date 4/6/2017

City Water Supply:

C1 - Static Pressure : 86
C2 - Residual Pressure: 78
C2 - Residual Flow : 1299

Demand:

D1 - Elevation : 4.764
D2 - System Flow : 198.539
D2 - System Pressure : 61.155
Hose (Demand) : 100
D3 - System Demand : 298.539
Safety Margin : 24.318



Fittings Used Summary

High Tech Fire Protection
123 Washington Ave Restaurant Area

Page 3
Date 4/6/2017

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	8	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
123 Washington Ave Restaurant Area

Page 4
Date 4/6/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
L1	11.0	5.6	12.25	na	19.6	0.1	196	7.0
L2	11.0	5.6	12.3	na	19.64	0.1	196	7.0
L3	11.0	5.6	12.75	na	20.0	0.1	196	7.0
L4	11.0	5.6	13.92	na	20.89	0.1	196	7.0
L5	11.0	5.6	15.96	na	22.37	0.1	196	7.0
L6	11.0		21.23	na				
P*	0.0		17.01	na				
L7	11.0	5.6	17.49	na	23.42	0.1	196	7.0
L8	11.0	5.6	17.68	na	23.55	0.1	196	7.0
L9	11.0	5.6	18.45	na	24.05	0.1	196	7.0
L10	11.0	5.6	19.94	na	25.01	0.1	196	7.0
L11	11.0		21.57	na				
L12	11.0		32.42	na				
L13	13.5		33.24	na				
L14	13.5		41.35	na				
TOR	3.0		49.83	na				
TOV	1.0		54.08	na				
BOV	-6.0		63.56	na				
UG1	-6.0		63.6	na				
UG2	-6.0		63.67	na				
UG3	-6.0		63.69	na				
TEST	0.0		61.15	na	100.0			

The maximum velocity is 17.43 and it occurs in the pipe between nodes L11 and L12

Final Calculations - Hazen-Williams

High Tech Fire Protection
123 Washington Ave Restaurant Area

Page 5
Date 4/6/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
L1	19.60	1.682		0.0	4.300	12.250				
to L2	19.6	120.0 0.0126		0.0	0.0	0.0			K Factor = 5.60	
L2	19.64	1.682		0.0	4.300	0.054				Vel = 2.83
to L3	19.64	120.0 1.682		0.0	9.900	12.304			K Factor = 5.60	
L3	39.24	0.0455		0.0	0.0	0.0				Vel = 5.67
to L4	39.24	120.0 1.682		0.0	9.900	0.450			K Factor = 5.60	
L4	20.00	0.0973		0.0	12.000	1.168				Vel = 8.55
to L5	20.00	120.0 1.682		0.0	12.000	13.922			K Factor = 5.60	
L5	59.24	0.1702		0.0	0.0	0.0				Vel = 11.57
to L6	59.24	120.0 1.682	1T	9.9	9.700	15.964			K Factor = 5.60	
L6	22.37	0.2684		0.0	9.900	0.0				Vel = 14.80
to L11	22.37	120.0 2.635		0.0	11.500	21.225				
L6	0.0	0.0302		0.0	0.0	0.0				Vel = 6.03
to L7	0.0	120.0 2.635		0.0	11.500	0.347				
L7	102.51	0.0302		0.0	0.0	21.572			K Factor = 22.07	
to L8	102.51	120.0 1.682		0.0	11.300	17.487			K Factor = 5.60	
L8	23.42	0.0175		0.0	0.0	0.0				Vel = 3.38
to L9	23.42	120.0 1.682		0.0	11.300	0.198			K Factor = 5.60	
L9	23.55	0.0633		0.0	12.000	17.685				Vel = 6.78
to L10	23.55	120.0 1.682		0.0	12.000	0.760			K Factor = 5.60	
L10	24.05	0.1361		0.0	11.000	18.445				Vel = 10.25
to L11	24.05	120.0 2.157	1T	12.307	10.700	19.942			K Factor = 5.60	
L11	25.01	0.0708		0.0	12.307	0.0				Vel = 8.43
to L12	25.01	120.0 2.157	1X	10.461	29.500	21.572				
L12	102.51	0.2715		0.0	10.461	0.0				Vel = 17.43
to L13	102.51	120.0 2.157	1V	4.307	2.700	32.423				
L13	0.0	0.2714		0.0	4.307	-1.083				Vel = 17.43
to L14	0.0	120.0 2.635	1V	5.903	56.800	33.242				
L14	198.54	0.1024		16.474	22.377	0.0				Vel = 11.68
to TOR	198.54	120.0 3.26	3V	20.159	87.900	41.353				
TOR	0.0	0.0363		0.0	20.159	4.548				Vel = 7.63
to TOV	0.0	120.0 3.26	1Fsp	0.0	10.700	49.827				
TOV	198.54	0.0364		0.0	0.0	3.866			* Fixed loss = 3	Vel = 7.63
to BOV	0.0	120.0 3.26	1Zia	0.0	2.000	54.082				
BOV	198.54	0.0360		0.0	0.0	9.411			* Fixed loss = 6.379	Vel = 7.63

Final Calculations - Hazen-Williams

High Tech Fire Protection
123 Washington Ave Restaurant Area

Page 6
Date 4/6/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BOV to UG1	0.0 198.54	6.16 140.0 0.0012	1E	20.084 0.0 0.0	7.000 20.084 27.084	63.565 0.0 0.033		Vel = 2.14		
UG1 to UG2	0.0 198.54	6.16 140.0 0.0012	1T 1G	43.037 4.304 0.0	10.000 47.341 57.341	63.598 0.0 0.071		Vel = 2.14		
UG2 to UG3	0.0 198.54	8.27 140.0 0.0003	1T	55.354 0.0 0.0	25.000 55.354 80.354	63.669 0.0 0.024		Vel = 1.19		
UG3 to TEST	0.0 198.54	6.16 140.0 0.0012	1E 1G	20.084 4.304 0.0	25.000 24.388 49.388	63.693 -2.599 0.061		Vel = 2.14		
	100.00 298.54					61.155		Qa = 100.00 K Factor = 38.18		