



FIRE ALARM PLAN
 SCALE: 1/8"=1'-0"

SHEET NOTES:

- ◆ ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW, PRESSURE SWITCHES, TAMPER SWITCHES AND POST INDICATING VALVES ASSOCIATED WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).
- ◆ ADDRESSABLE MONITOR MODULE PROVIDED TO MONITOR THE KITCHEN HOOD FIRE SUPPRESSION SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	2/2/2017
1	REVISIONS PER AHJ	5/10/2017

CUNNINGHAM
Security Systems
 10 Princes Point Road, Yarmouth, Maine 04096
 Office: 207.846.3350 • Fax: 207.846.6080

123 WASHINGTON AVENUE
PORTLAND, MAINE 04101
FIRE ALARM PLAN

DRAWN	JPB UNICAD JOB #17019
CHECKED	WAYNE B. HAWS NICET IV 90496
DATE	5/10/2017
REVISION	1
SCALE	1/8"=1'-0"

Shop drawings created by
 5794 W. 4900 St.
 Hesper, UT 84313
 Office: 801.985.0410
UNICAD Inc.
 Fire Alarm Design & Drafting Services

FA-2