SHEET NOTES:

1. ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW, PRESSURE SWITCHES, TAMPER SWITCHES AND POST INDICATING VALVES ASSOCIATED WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).
2. ADDRESSABLE MONITOR MODULE PROVIDED TO MONITOR THE KITCHEN HOOD FIRE SUPPRESSION SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

TRUE NORTH / PROJECT NORTH

FIRE ALARM PLAN

SCALE: 1/8"=1'-0"

RESERVED FOR CITY STAMP

Reviewed for Code Compliance
Inspections Division
Portland, Maine
Date: 06/19/17

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	2/2/2017
1	REVISIONS PER AHJ	5/10/2017

CUNNINGHAM
Security Systems
10 Princes Point Road, Yarmouth, Maine 04096
Office: 207.846.3350 • Fax: 207.846.6080

123 WASHINGTON AVENUE
PORTLAND, MAINE 04101
FIRE ALARM PLAN

DRAWN	JPB UNICAD JOB #17019
CHECKED	WAYNE B. HAWS NICET IV 90496
DATE	5/10/2017
REVISION	1
SCALE	1/8"=1'-0"

shop drawings created by:
5794 W. 4600 So.
Hooper, UT 84315
Office: 801.985.0410
UNICAD Inc.
www.unicad.net
Fire Alarm Design & Drafting Services

FA-2