CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/01/17

Google Earth feet 90 meters 20

No Change to foot Print of building

CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/01/17

RTU'S 1,2,3,4 ON Roof

ROOFTOP UNITS									
TAG	MFG	MODEL #	HTG (BTU)	DESIGN CFM	VOLT	PHASE	MCA	MAX FUSE	NOTES
RTU-1	TRANE	YSC072F3RMA	120,000		208-230	3	36.5	50	
RTU-2	TRANE	YSC072F3RMA	120,000		208-230	3	36.5	50	
RTU-3	TRANE	YSC060G3RMA	80,000		208-230	3	28.2	40	
RTU-4	TRANE	YSC060G3RMA	80,000		208-230	3	28.2	40	

FIRST FLOOR
SCALE 1/8"=1'-0"

HVAC SERVICES, INC.
Design • Build • Install • Service
73 BRADLEY DRIVE
WESTBROOK, MAINE 04092
(207) 854-HVAC (4822)

REVISIONS

NO.	NOTES

PROJECT: 123 WASHINGTON

SHEET TITLE: FIRST FLOOR

SCALE: 1/8"=1'-0"
DRAWN BY: TJF
CHECKED BY:
PRINT TO SCALE: 36x24
DATE: 5-5-2017
SHEET No. M-1