



**PORTLAND WATER DISTRICT**  
**225 Douglass Street**  
**Portland, ME 04104**  
**Asset Management and Planning Dept.**

**Legend**

|                |                    |                    |           |
|----------------|--------------------|--------------------|-----------|
| ● Air Valve    | ● Connection       | ⊕ Combined Service | ● Manhole |
| ⊖ Blow Off     | ● Attribute Change | ⊕ Domestic Service | ● CSO     |
| ⊕ By Pass      | ▲ Reducer          | ⊕ Fire Service     | → Gravity |
| ⊕ Distribution | ● Hydrant          | ● Private Hydrants | → Force   |
| ⊕ Transmission | ● Hydrant Control  | ⊕ Meter Pits       |           |

**Hydrant Flow Testing Data**

**104 North Street**  
**Portland**

This map depicts flow testing data for the selected hydrants from PWD's asset management system. Note: a static pressure with a zero residual pressure and a flow hydrant that is the same as the test hydrant depicts a single-hydrant static pressure-only test.

Drawn By: C.K  
 Scale: As Noted

Prepared For: Scott E. Garland  
 Sprinkler Systems Inc.  
 Date: 01/14/2013