

COLUMN SCHEDULE			
MARK	SIZE	BASE PLATE SIZE	NOTES
C1	HSS 4x4x5/16	PL 1/2 x 0-9" x 0-8"	DETAIL L/S-2.1
C2	HSS 4x4x5/16	PL 3/4" x 1'-0" X 1'-0"	DETAIL B/S-2.1
C3	HSS 5x5x5/16	PL 3/4" x 1'-2" X 1'-2"	DETAIL B/S-2.1
C4	16" O CIP CONC.	NOT APPLICABLE	(?) #7 VERTS W/ 14" HOOKS INTO FTG, SEE DETAIL A/S-3.3

FOUNDATION/ SLAB PLAN


NOTES:

- SEE S1.0 GENERAL NOTES FOR ADDITIONAL REQUIREMENTS AND INFORMATION
- ALL FOOTINGS ARE 10" DEEP x 1'-8" WIDE x CONT. WITH (2) # 5 BARS LONGITUDINAL AND #4 TRANSVERSE BARS @ 32" UNO
- STEP IN TOP OF WALL IS INDICATED THUS: AND SHOWS LOWER SIDE OF WALL.
- STEP IN TOP OF FOOTING IS INDICATED THUS: AND SHOWS LOWER FOOTING.
- TOP OF FOOTING ELEV.=96'-0", UNLESS INDICATED THUS: (XXX'XX), COORDINATE BOTTOM OF FOOTING ELEVATION W/ GRADING PLAN AND SOILS REPORT REQUIREMENTS
- BOTTOM OF ALL FOOTINGS TO BE 4'-6" MIN BELOW EXTERIOR GRADE -TYP UNO
- TOP OF WALL ELEV.=VARIES, INDICATED THUS: TW=XXX'-XX
- TOP OF PILASTER ELEVATION=99'-6" -TYP UNO
- REFERENCE ELEVATION 100'-0" USED IN STRUCTURAL DRAWINGS CORRELATES TO CIVIL ELEVATION XXX'XX' -TYP UNO VERIFY W/ CIVIL DRAWINGS.

CONCRETE FOOTING SCHEDULE		
MARK	SIZE	FTG REINFORCING
CF-01	22" WIDE x 10" THICK x CONT. STRIP FTG	(3) #5 CONT. #5 HOOK DOWELS @ 32"
CF-02	SEE PLAN x 2'-0" THICK x CONT. RETAINING WALL FTG	#6 @ 12" O.C. CONT. TOP AND BOT #8 TRANSVERSE @ 12" O.C. TOP AND BOT
F3	3'-0" SQ x 14" THICK ISOLATED FTG	#4 @ 12" O.C. E.W. TOP MAT & #4 @ 12" O.C. BOT MAT
F9	9'-0" SQ x 18" THICK ISOLATED FTG	#5 @ 12" O.C. E.W. TOP MAT & #5 @ 6" O.C. BOT MAT
F6	6'-0" SQ x 18" THICK ISOLATED FTG	#6 @ 12" O.C. E.W. TOP MAT & #6 @ 6" O.C. BOT MAT

NOTE:

- ALL EXTERIOR FOOTINGS TO BEAR 4'-0" BELOW FINISH GRADE MIN FOR FROST PROTECTION -TYP. VERIFY W/ CIVIL AND ARCH.
- SUPPLEMENTAL REINFORCING MAY ALSO BE REQUIRED IN PLANS AND SECTIONS.



© 2017 RYAN SENATORE ARCHITECTURE

RESIDENCES
155 SHERIDAN STREET
PORTLAND, MAINE

RSA
RYAN SENATORE
ARCHITECTURE
565 CONGRESS STREET
PORTLAND, MAINE 04101
207-450-6414
senatorearchitecture.com

CONSULTANTS:
Structural Integrity
1111 North Commercial Street
Portland, ME 04107
Tel: 207-744-1111
www.structuralintegrity.com
SI#17-0159

REVISIONS:

DATE: 1/16/2018
PROJECT No. 17-0159
DRAWN BY: CJO
CHECKED BY: CJO
SCALE: AS NOTED

SHEET TITLE:
FOUNDATION PLAN

S-1.1