



**CUNNINGHAM**  
SECURITY SYSTEMS

February 29, 2016

Fire Prevention Bureau  
Portland Fire Department  
380 Congress Street  
Portland, ME 04101  
(207) 756-8096  
Fax#: (207) 874-8410

To Whom It May Concern:

This letter is to inform you that on January 8, 2016, we completed the installation, programming and testing of the new fire alarm system in the building located at 80-82 North Street in Portland, Maine. The new system and devices consisted of the replacement of the existing fire alarm control panel with a new addressable fire alarm control panel, replacement of all existing common area fire alarm smoke detectors, replacement of all existing common area heat detectors, replacement of all existing common area pull stations and replacement of all common area existing horn/strobe units. The new fire alarm control panel is located in the basement and is controlled by a new annunciator with a locked cover and is located in the main entry of 80 North Street. These fire alarm devices are located in the building's common areas and are not in any of the apartments. These new devices were all programmed and tested to NFPA 72 standards. These devices were found to be fully functional at that time. No signals were sent to our central monitoring station as this is a local system only.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Sneider, Manager

cc: Acct. File

## Jeff MacKenzie

---

**From:** Bill Weeks  
**Sent:** Tuesday, March 01, 2016 12:46 PM  
**To:** Jeff MacKenzie  
**Subject:** Fwd: 80-82 North Street  
**Attachments:** img-301103347-0001.pdf

*Sent from my Verizon Wireless 4G LTE Droid*

----- Forwarded message -----

**From:** Ronald Sneider <[RSneider@cunninghamsecurity.com](mailto:RSneider@cunninghamsecurity.com)>  
**Date:** Mar 1, 2016 10:36 AM  
**Subject:** 80-82 North Street  
**To:** Bill Weeks <[Weeks@risbara.com](mailto:Weeks@risbara.com)>  
**Cc:**

Hi Bill,

Attached is a letter confirming that we installed, programmed and tested a new fire alarm system in the buildings located at 80-82 North Street in Portland.

Please let me know if you have any questions or if I can be of any further assistance in this matter.

Thanks

Ron Sneider  
Cunningham Security Systems  
10 Princes Point Road  
Yarmouth, ME 04096  
P: 207-846-3350  
F: 207-846-6080  
[rsneider@cunninghamsecurity.com](mailto:rsneider@cunninghamsecurity.com)