Planning & Urban Development Department

Director of Planning and Urban Development Jeff Levine

> Inspection Services, Director Tammy M. Munson

September 26, 2014

STEPHENS CLARK B 31 EAST OXFORD ST PORTLAND, ME 04101

CBL: 013 B007001

Located at: 31 EAST OXFORD ST

Certified Mail 7010 3090 0002 3273 7576

Dear Mr. Stephens,

An evaluation of the above-referenced property (29 Anderson Street #2) on 09/26/2014 shows that the structure fails to comply with Chapter 6.Article V. of the Code of Ordinances of the City of Portland, The Housing Code. Attached is a list of the violations.

This is a notice of violation pursuant to Section 6-118 of the Code. All referenced violations shall be corrected within 14 days of the date of this notice. A re-inspection of the premises will occur on 10/10/2014 at which time compliance will be required. Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code.

This constitutes an appealable decision pursuant to Section 6-127 of the Code.

Please feel free to contact me if you wish to discuss the matter or have any questions.

Please be advised that the Portland City Council has amended the Building regulations to include a \$150.00 re-inspection fee. This violation will automatically cause a re-inspection at no charge. If there are any subsequent inspections, however, the \$150.00 fee will be assessed for each inspection.

Sincerely

Chuck Fagone

Code Enforcement Officer

(207) 874-8789

CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager STEPHENS CLARK B		Inspector Chuck Fagone	Inspection Date 9/26/2014
31 EAST OXFORD ST	013 B007001	Re-Inspect 14 Days	Complaint-Inspection

Code Int/Ext Floor Unit No. Area Compliance Date

1) 6-108. (b)

Interior

Kitchen

Violation:

INTERIOR FLOORS, WALLS, CEILINGS AND DOORS

Notes:

Every floor, wall, ceiling, and door shall be in a structurally sound condition and in good repair and shall be substantially vermin proof. *Kitchen ceiling leaks and tile ceilings need replacing.*

2) 6-116. (c)

Interior

Hall/Stairs

Violation:

EGRESS OBSTRUCTIONS

Notes:

Every hallway, stairway, corridor, exit, fire escape door or other means of egress shall be kept clear of obstructions at all times. *Debris, furniture and other items in hallway and stairwells*.

obstructions at all times. Debns, furniture and other items in hallway and s

3) 6-116. (e)

Interior

Smoke Alarms

Violation:

FIRE PROTECTION

Notes:

Every dwelling, dwelling unit, rooming house and rooming unit shall comply with the applicable provisions of the most current edition of the National Fire Protection Association Life Safety Code, and with all other applicable state statutes and regulations. *Smoke detectors missing throughout*

Comments: Violations exist of leaking ceiling, no smoke detectors and blocked hallways (egress).

Strengthening a Remarkable City,
Building a Community for Life
PORTLAND
MAINE

Inspection Services Division

389 Congress Street, RM 315 Portland, Maine 04101-3509





MAILED FROM ZIP CODE 0 4101

218

NIXIE

15 DE 1009

0010/17/14

RETURN TO SENDER NOT DELIVERABLE AS ADDRESSED UNABLE TO FORWARD

BC: 04101357190 *1569-09647-08-3 Ավուկինդիկներիրկինկիկիկիկիկինկիլու

H84N9199 9339