

~~1/24/02 Close in soled~~
Called on Am & Called (D)

2/7/02 Close in - Framing ok - plumbing needs permit. & Master plumber review. The vent pipe shown on plan is really a roof drain - needs to be addressed. Gave ok to close in any areas except plumbing - most is accessible in basement. Kitchen sink is existing and originally had a mechanical vent (over 10' from Bldg drain).
Mike C. did electrical. J.B.

3/1/02 Final inspection Plumbing has been resolved. OK.
Can clo subject to electrical approval. JR



Certificate of Occupancy

LOCATION 127 Cumberland Ave

CBL 013 D015001

Issued to Wong Kathleen /Dugan, Ben

Date of Issue 03/07/2002

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 01-1557 , has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Change of use from vacant store to apartment

Use Group R2 Type 5b (Boca 1999)

Limiting Conditions:

This changes the use from a store to a one(1) bedroom apartment.
No other use is permitted

This certificate supersedes certificate issued

Approved:

3/7/02
(Date)

Jon Reed
Inspector

[Signature]
Inspector of Buildings

Wong Kathleen /Dugan, Ben

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.