CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/30/15

① Ceiling Details Kitchen Area

- 2x10 Joists 16" O.C. (Existing)
- 3" mineral wool batt
- RC-1 channel or equivalent
- 2 Layers 5/8" Sheetrock Fire code X

② Ceiling Details Chocalate Shop Area

- 2x10 Joists 16" OC (Existing)
- Plaster + Lathe (existing)
- 3/4 txG Bead Board (Existing)
- RC-1 channel ~~or equivalent~~ or wood firring strip if necessary
- Single layer Fire code X 5/8 sheet rock