RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/30/15

(3) Existing walls are plaster, panel, and single layer sheet rock to be left in existing condition.

All new partition walls to be:

- 2x4 wood framing
- single layer 5/8 fire code sheet rock on both sides

(4) Entire kitchen wall to be an additional steel framed 2x4 wall in front of existing wood wall. as shown:

- New 2x4 metal studs
- single layer 5/8 sheetrock fire code X