

Side View Hood




Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Bourgoin + Sons
Dan
749 1878
dan.bourgoin@gmail.com

Date: 12/08/16

SECOND FLOOR





Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/08/16

Duct air fans view
[Back of Building]

Hinge kit

Exhaust fan

18"

roof
soffit box

second floor deck

makeup air fan

wall support brace

High temp clean out doors

14x14 grease duct solid weld
from hood to fan base.

Approx 4'
Ally

grade

