

Ann Machado - 56 Washington Ave

From: David Margolis-Pineo
To: Ann Machado
Date: 7/12/2011 2:41 PM
Subject: 56 Washington Ave
CC: Barbara Barhydt; Danielle West-Chuhta; Marc Spiller

Ann,

Marc Spiller of Operations just checked out 56 Washington Ave for the proposed construction of a three foot overhang into the street right of way.

If the applicant keeps the full eight foot (96") clearance from the highest point in the sidewalk along the proposed length of the overhang to the lowest point of the overhang then Public Services is ok with the proposed easement request.

RECEIVED

JUL 12 2011

Dept. of Building Inspections
City of Portland Maine