107 Washington Ave
Lead Paint Determination

Room / Area	Component	Material	Color	Lead mg/cm2
Exterior	Concrete Block	Concrete	White	<.50
Exterior	Concrete Block	Concrete	Tan	<.50
Exterior	Concrete Block	Concrete	Gray	<.50
Exterior	Exterior Trim	Wood	White	<.50
Interior	Concrete Block	Concrete	White	<.50
Interior	Concrete Block	Concrete	Tan	<.50
Interior	Concrete Block	Concrete	Gray	<.50
Interior	Structural Steel	Steel		<.50
		B = Brick W = Wood Pl = Plaster G = Gypsum M = Metal	BR - Brown Bl = Blue W = White Y = Yellow GR =Green	0.5 mg/cm2 or higher OSHA Regulated