
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager MECAP LLC		Inspector Suzanne Hunt	Inspection Date 11/7/2008
Location 85 CUMBERLAND AVE	CBL 013 I027001	Status Re-Inspect 14 Days	Inspection Type Complaint-Social Services/Gener

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 110.26 (B)	Interior	1		Hallway	
Violation:	NEC 2005/NFPA 70				
Notes:	remove washer and dryer from hallway				
2) 6-108.b	Interior	1		Hallway	
Violation:	Interior floors, walls, ceilings and doors				
Notes:	repair plaster wall beneath egress stairway in hallway.				

Comments: pass for ga