STATE OF MAINE
Department of Environmental Protection

Notice of Intent to Remove an Underground Oil Storage Tank Facility and/or Underground Product Piping

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 04/06/15

Notifications: (Sent a copy of this notice)
- [x] Maine DEP
- [x] Certified Tank Installer *(as required)*
- [ ] Local Fire Department
- [ ] Site Assessor *(as required)*

Facility Information

Facility Name: 7-11 # 32532 Registration #: 155

27 Washington Ave — Facility Address
Portland — Town

7 ELEVEN INC. — Owner Name
P.O. BOX 711 DALLAS TX — Owner Address
(716) 830-9807 — Owner Phone

Identification of Tank / Piping to be removed

[ ] Tank #	7	Tank Size:	10,000	Tank Age:	08/01/1992
[x] Piping	F/GLASS	Product:	UNLEADED	Piping Age:	08/01/1992
[ ] Tank #	8	Tank Size:	8000	Tank Age:	08/01/1992
[x] Piping	F/GLASS	Product:	PREMIUM	Piping Age:	08/01/1992
[ ] Tank #		Tank Size:		Tank Age:	
[ ] Piping		Product:		Piping Age:	

Additional Removal Information

[x] YES / [ ] NO — Did any tank or piping above store Class I liquids (e.g., gasoline, aviation fuel) within the last 12 months?

IF YES, REMOVAL OF THE TANK(S) OR PRODUCT PIPING MUST BE DONE UNDER THE DIRECTION OF A MAINE CERTIFIED TANK INSTALLER AND THE INERTING METHOD AND CLEANING LOCATION MUST BE IDENTIFIED.

Inerting Method: NITROGEN — Cleaning Location: ON-SITE

PAUL THOMPSON 289 — Maine Certified Tank Installer Name and ID Number
Paul Thompson — Installer Signature
3-30-15 — Date

Note: *Site assessments must be conducted in accordance with Chapter 691(11)(A)(1)(d) and Appendix P.*

Site Assessor (if applicable): AECOM (DAN TAYLOR) — Site Assessor
(978) 905-2497 — Phone Number

Contractor who will remove the ~~tank~~: PIPING — GAFTEK LLC. — Contractor
(207) 217-6515 — Phone Number

Expected Date of Removal: 4/6/15 — Month/Date/Year

I hereby provide Notice that I intend to properly remove the underground oil storage tank facility as described above.

MARK BECKER COMPLIANCE SPEC — Owner or Authorized Employee Name and Title
Mark Becker — Signature
3/26/2015 — Date

*NOTE: WHEN TANK AND/OR PIPING HAS BEEN REMOVED, PLEASE FILL OUT AND SEND IN THE **REMOVAL CONFIRMATION.***

EXPIRES AFTER SIX (6) MONTHS IF DEPARTMENT DOES NOT RECEIVE REMOVAL CONFIRMATION