

•  
•  
•  
•  
•  
•

389 Congress St.Rm 315  
Portland, ME 04101  
Phone: (207)874-8700  
Fax: (207)874-8716

# facsimile transmittal


**To:** Mike Scarks/ Stan Gawron **From:** Mike Nugent

**Fax:** 883-0361 **Date:** November 22, 2002

**Phone:** 883-6307 **Pages:** 1

**Re:** Third Floor Plan/Nissen's Building

- Urgent     For Review     Please Comment     Please Reply     Please Recycle



•   •   •   •   •   •   •   •

I have commenced the review of the above project and have the following comments:

- 1) Please Provide all available plans and specs for this project.
- 2) The Large conference room appears to have non-compliant egress based on the potential occupancy load (80).

