Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/13/16

ON FACE OF MASONRY BRICK
UNLESS OTHERWISE NOTED.

PLUMBING REQUIREMENTS
52 OCCUPANTS :
16-35 MALE / 16-35 FEMALE

REQUIREMENTS
WATER CLOSETS
MALE: 2 FEMALE: 3

URINALS
MALE: 1

LAVATORIES
MALE: 1 FEMALE: 1

1 A101B PROPOSED SPOTME TENANT SPACE LAYOUT
SCALE: 1/4"=1'-0"

BARBA+WHEELOCK
ARCHITECTURE SUSTAINABILITY PRESERVATION
500 CONGRESS STREET
PORTLAND, MAINE 04101
207 772 2722
WWW.BARBAWHEELOCK.COM

NOT FOR CONSTRUCTION

SpotMe
935 W CHESTNUT STREET, SUITE 650
CHICAGO, IL 60642

PARTIAL FLOOR PLAN

ISSUED FOR/REVISION:
OWNER REVIEW

DRAWN BY:
BAW

Copyright 2016 Barba + Wheelock

SHEET SIZE:
22" x 34"

DATE:
09/06 / 2016

WASHINGTON STREET
PORTLAND, MAINE

A102