Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/13/16

SLAB PLAN

SCALE 1/8"=1'-0"

NOTES:
1. SEE SHEET S1.0 FOR GENERAL STRUCTURAL NOTES
2. (E) INDICATES EXISTING TO REMAIN, (N) INDICATES NEW -TYP
3. CONTRACTOR TO SHORE ALL EXISTING CONSTRUCTION AS NEEDED TO MAKE ALTERATIONS
4. NOTIFY ARCH OF ANY DISCREPANCIES FOUND IN THE FIELD
5. VERIFY ALL OPENINGS LOCATION AND DIMENSIONS W/ LATEST ARCHITECTURAL DRAWINGS -TYP

SEE ARCHITECTURAL PLANS FOR ADDITIONAL INFORMATION REGARDING SLAB PLACEMENT ETC. -TYP

ROOF FRAMING PLAN

SCALE 1/8"=1'-0"

NOTES:
1. SEE SHEET S1.0 FOR GENERAL STRUCTURAL NOTES
2. (E) INDICATES EXISTING TO REMAIN, (N) INDICATES NEW -TYP
3. CONTRACTOR TO SHORE ALL EXISTING CONSTRUCTION AS NEEDED TO MAKE ALTERATIONS
4. NOTIFY SI Inc. OF ANY DISCREPANCIES FOUND IN THE FIELD
5. VERIFY ALL OPENINGS LOCATION AND DIMENSIONS W/ LATEST ARCHITECTURAL DRAWINGS -TYP

CUT BACK EXISTING DECKING TO CANTILEVER FROM LAST WF BEAM. **NOTE**: DECKING SHALL **NOT** "BEAR" ON NEW LIGHT GAGE COURTYARD WALLS BELOW. PROVIDE 1" MINIMUM DEFLECTION TRACK OR CLIPS AT HEAD OF WALL -TYP.

STRUCTURAL GENERAL NOTES

DESIGN LOADS: International Building Code; IBC 2009 Edition, except as noted
Occupancy Category, Table 1604.5 — II Standard

Wind	IBC 1603.1.4, ASCE 7-05	Analytic Method	
	3 Second Gust Velocity	100 mph	
	Importance Factor	1.0	
	Building Category and Internal Pressure Coefficient		
	IBC 1609.2, ASCE Figure 6-5	Enclosed	
	Exposure	B	

SECTION A S1.1 3/4"=1'-0

SECTION B S1.1 3/4"=1'-0

TYPICAL JOINTS AT INTERIOR SLAB-ON-GRADE
NO SCALE

STATE OF MAINE — AARON C. JONES No. 10968 — LICENSED PROFESSIONAL ENGINEER

Structural Integrity Consulting Engineers, Inc.
SI # 16-0129
77 Oak Street
Portland, ME, 04101
p. 207-774-4614
f. 866-793-7835
www.structuralinteg.com
BUILD WITH CONFIDENCE
© 2012 Structural Integrity Consulting Engineers, Inc.

© 2016 RYAN SENATORE ARCHITECTURE

NISSEN BUILDING - COURTYARD
75 WASHINGTON STREET
PORTLAND, MAINE

RSA
RYAN SENATORE
ARCHITECTURE
565 CONGRESS ST. SUITE 304
PORTLAND, MAINE 04101
207-650-6414
senatorearchitecture.com

CONSULTANTS:
STRUCTURAL:
Structural Integrity
77 Oak Street
Portland, ME 04101
207-774-4614

REVISIONS:

DATE:	31 AUGUST, 2016
PROJECT No.	
DRAWN BY:	MKL
CHECKED BY:	
SCALE:	AS NOTED

SHEET TITLE: STRUCTURAL PLANS AND SECTIONS

S1.1