

INSTALLATION NOTES

1. INSULATE ALL HOOD MAKEUP AIR DUCTWORK WITH 2" FSK DUCT WRAP.
2. INSULATE ALL GREASE DUCT WITH TWO (2) LAYERS OF 1½" 3M FIRE BARRIER DUCT WRAP 615+ IF LOCATED WITHIN 18" OF COMBUSTIBLE CONSTRUCTION.
3. DESIGN ALL HOOD MAKEUP DUCTWORK AT 2" W.G. AND SEAL PER SMACNA CLASS B SEALING STANDARDS.
4. KITCHEN HOOD EXHAUST DUCTWORK SHALL BE CONTINUOUSLY WELDED 16 GAUGE STEEL INSTALLED IN ACCORDANCE WITH NFPA 96 REQUIREMENTS. MAINTAIN A MINIMUM OF 18" TO COMBUSTIBLE CONSTRUCTION.
5. INSTALL GREASE DUCT ACCESS PANELS AS INDICATED AND CONSTRUCT PER NFPA 96. OPENINGS TO BE A MINIMUM OF 1½" UP FROM THE BOTTOM OF THE DUCT.

FOR CONSTRUCTION

Haley's Metal Shop, Inc.
"Since 1917"

HALEY'S METAL SHOP, INC.
539 ELM STREET
BIDDEFORD, MAINE 04005
PH: 207-284-8571, FAX: 207-284-9597

DATE: 12/22/16

SCALE: 3/8"=1'-0"

CONG TU BOT RESTAURANT
PORTLAND, MAINE
KITCHEN VENTILATION PLAN

HVAC

M-1

Reviewed for Code Compliance
Inspections Division
Date: 01/24/17