



CUNNINGHAM
SECURITY SYSTEMS

March 01, 2017

Fire Prevention Bureau
Portland Fire Department
380 Congress Street
Portland, ME 04101
(207) 756-8096
Fax#: (207) 874-8410

To Whom It May Concern:

This letter is to inform you that on February 27, 2017, we completed the programming and testing of the new fire alarm devices installed in the new OnPoint space located in the building at 75 Washington Avenue in Portland, ME. These new devices were tied into the building's existing fire alarm control panel and programmed and test to NFPA 72 standards with test signals sent from these devices and received at our Central Monitoring Station. These devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Sneider, Manager

cc: Acct. File