

HIGH TECH FIRE PROTECTION

PO Box 156 • Minot, ME 04258-0156

Phone: (207)998-2551 • Fax: (207)998-4187



NFPA Letter of Compliance

Date: October 6, 2015

To: Landmarc Construction

From: Richard Smith

Re: Sprinkler System Compliance Letter

High Tech Fire Protection has retrofitted an existing NFPA 13 sprinkler system for (Roustabout) located at 75 Washington Ave Portland, ME. This system is in accordance with contract # 2015-12.

High Tech Fire Protection hereby guarantees the design, materials and workmanship to meet the requirements necessary for an approved NFPA #13 Automatic Fire Sprinkler System per State and local authority.

Sincerely,
Richard Smith
High Tech Fire Protection
207-998-2551
RSmith@htfp.me

*Specializing in Commercial and Residential Fire Sprinkler Systems
Design • Installation • Inspection • Service*



State of Maine
Department of Public Safety
Fire Sprinkler System Permit



FSP11966

ROUSTABOUT RESTAURANT

Located at: 75 WASHINGTON AVE
In the Town of: PORTLAND
Occupancy/Use: Other
Type of System: NFPA 13

Permission is hereby given to:

HIGH TECH FIRE PROTECTION CO., INC.
Contractor License # FSC102

to begin installation according to plans submittal approved by the Office of State Fire Marshal. No departure from the application submittal shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 1337. Nothing herein shall excuse the holder of this permit from failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. This permit shall be displayed at the construction site or be made readily available.

Permit issued 7/28/2015

Permit expires at midnight on 01/27/2016

The expiration date applies only if the installation has not begun by that date and no permission has been granted to extend the date. Once installation begins, then the permit is valid as long as work is continuous

John E. Morris
Commissioner

The type of Fire Department Connection and its location is to be according to the Local Fire Department.

Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a sprinkler system contractor shall provide to the commissioner a copy of the permit signed by the certified responsible managing supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan.

Inspection
Dates: 8-13-15 / 9-22-15

Job completed, tested and verified by date of
9-24-15 Edward Portier

RMS for this job: Poulin Edward M.



FIRE PROTECTION

(formerly All State Fire Equipment)
3 Tallwood Drive, Unit 3, Bow, NH 03304
Phone (603) 717-7300 * Fax (603) 717-7303
MA-CR 4628

**Pre-Engineered
Kitchen System Inspection Report**

DATE: 10-14-15 TIME: _____ AM PM

TYPE: INSPECTION / RECHARGE / NEW INSTALL / RENOVATION

CUSTOMER: Roustaabout
ADDRESS: 75 Washington Ave
CITY, STATE, ZIP: Portland ME
PHONE: _____
OWNER / MANAGER: _____

MAKE / MODEL: Anson R102
SIZE: 4.5 gal
CYLINDER LAST HT DATE: 2015 x 2
NEXT CYLINDER SERVICE DUE DATE: 2027
CYLINDER LOCATION: Fire Cabinet

DESCRIPTION	YES	NO	N/A
1. SYSTEM TIED INTO FIRE ALARM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. ALL TAMPER SEALS INTACT	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. CORRECT NOZZLE COVERAGE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. HOOD & DUCT PROPERLY SEALED / CLEANED	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. OPERATION OF DETECTION LINE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. CYLINDER RELEASE MECHANISM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. PIPING & CONDUIT SECURE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. NOZZLES CLEANED QTY <u>11</u> REPLACED QTY _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. NOZZLE CAPS IN PLACE QTY <u>11</u> (M) _____ (R) _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. NOZZLE CAPS REPLACED QTY <u>11</u> (M) _____ (R) _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. COPPER TUBING & FITTINGS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12. CHECKED GAS VALVE <u>1"</u> (MECH.) _____ (ELECT.) _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13. GREASE SHIELD PROTECTING FRYER	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14. CYLINDER(S) MOUNTS SECURE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

DESCRIPTION	YES	NO	N/A
15. CHECK CYLINDER(S) PRESSURE	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
16. CHECK / REPLACE CARTRIDGE (circle one)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17. CHECK MANUAL PULL STATION	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18. EXHAUST FAN(S) OPERATING	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19. FAN WARNING SIGN VISIBLE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20. HOOD FILTERS COMPLIANT	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. SYSTEM IS UL-300 COMPLIANT	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22. SYSTEM OPERATIONAL & ARMED	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
23. K-CLASS EXTINGUISHER	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
24. EXTINGUISHERS INSPECTED	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
25. EMERGENCY & EXIT LIGHTS LIT	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
26. POSI-SET ON WHEELED EQUIPMENT	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
27. FUSIBLE LINKS REPLACED	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
28. QTY. OF FUSIBLE LINKS: 360^ _____ 450^ _____ 500^ <u>5</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

EQUIPMENT (left to right): 14" Fryer, 32" upright Boiler, 36" Flat top, 36" Range,
24" broiler, over.

SAFETY NOTICE: Non-compliant systems may fail to extinguish/suppress a fire. Below are non compliant conditions that require immediate attention. CINTAS Fire Protection assumes no responsibility for system performance if these conditions are not corrected and/or verified by a CINTAS agent.

COMMENTS / NON-COMPLIANCE (see notes below):

() PRE UL-300 COVERAGES APPLY

1)

2)

3)

MATERIAL COST ITEM 1:

LABOR COST ITEM 1:

MATERIAL COST ITEM 2:

LABOR COST ITEM 1:

MATERIAL COST ITEM 3:

LABOR COST ITEM 1:

Total on site quote: \$ _____

_____ I accept quoted price please schedule service work to be completed.

_____ I decline quoted price and take full responsibility for non-compliance issues.

CINTAS Fire Protection Agent: Rob West

Date: 10-14-15

Customer's Authorized Agent: Anders Tallberg

Date: 10-14-15

Printed Agent's Name: Anders Tallberg

This report may be required to be forwarded to your current insurance provider and/or authority having jurisdiction.