Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/09/15

Christina Stacey - Re: Sign Permit #2185 - 59 Washington Ave.

From: Kit Paschal <kit@roustabout.me>
To: Christina Stacey <cstacey@portlandmaine.gov>
Date: 10/9/2015 11:31 AM
Subject: Re: Sign Permit #2185 - 59 Washington Ave.
Attachments: McMaster-Carr - Oval Threaded Connector with Large Opening, Type 316L Stainless Steel, 3:16" Diamete.pdf

---

We will be using 2 stainless steel carbines each with 880lb work load. I have attached the PDF below let me know if you have any more questions.

Thank you
Kit

On Fri, Oct 9, 2015 at 9:38 AM, Christina Stacey <cstacey@portlandmaine.gov> wrote:

> That is fine, I can use the rest of the existing application. One last thing - do you have the hardware/attachment details for how the sign will be attached to the bracket? We will need that to finalize the permit. Your sign maker can probably provide you this info.
>
> Thanks,
> Chris
>
> >>> Kit Paschal <kit@roustabout.me> 10/9/2015 9:20 AM >>>
> Hi Chris,
>
> We have decided to go with the blade sign. Attached below is the proposal with just the blade sign. Are you able to use the actual application that I sent you?
>
> On Thu, Oct 8, 2015 at 8:23 AM, Christina Stacey <cstacey@portlandmaine.gov> wrote:
>
>> Hi Kit,
>> I am in the process of reviewing the above-referenced application that you submitted for signs at the Roustabout restaurant. I am contacting you because the signs as proposed cannot be approved under the City's ordinance. In the B-4 zone, the ordinance allows only one sign for each tenant, so we can only approve either the blade sign or the wall sign, but not both. Please let me know how you would like to proceed with your application, or if you have any questions about this ordinance.
>> Yours,
>> Chris
>> Christina Stacey
>> Zoning Specialist - Inspections Division
>> City of Portland
>> 389 Congress St.
>> Portland, ME 04101
>> (207) 874-8695
>> cstacey@portlandmaine.gov

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/09/15

--
Kit Paschal
ROUSTABOUT
C- 508.364.8371
P- 207.536.4008
59 Washington Ave
Portland, Me.
roustabout.me

--
Kit Paschal
ROUSTABOUT
C- 508.364.8371
P- 207.536.4008
59 Washington Ave
Portland, Me.
roustabout.me