



**CUNNINGHAM**  
SECURITY SYSTEMS

October 16, 2015

Fire Prevention Bureau  
Portland Fire Department  
380 Congress Street  
Portland, ME 04101  
(207) 756-8096  
Fax#: (207) 874-8410

To Whom It May Concern:

This letter is to inform you that on October 9, 2015, we completed the installation, programming and testing of the new fire alarm devices installed in the Rousabout Restaurant space located in the building at 75 Washington Avenue in Portland, ME. These new devices were tied into the building's existing fire alarm control panel and programmed and test to NFPA 72 standards with test signals sent from these devices and received at our Central Monitoring Station. These devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Sneider, Manager

cc: Acct. File