Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/22/13

Planner: Benjamin Wallace Jr

Window Schedule

A: Andersen CW245 4'8 1/2" x 4'4 13/16" R.O.

(Meets or exceeds clear opening area of 5.7 sq. ft., clear opening width of 20"and clear opening height of 24".)

B: Andersen CXW25 5'11 5/8" x 4'11 7/8" R.O.

(Meets or exceeds clear opening area of 5.7 sq. ft., clear opening width of 20"and clear opening height of 24".)

C: Andersen AW321W 5'11 7/8" x 2'4 3/8"