

R.J. ENTERPRISES, Inc.
P.O. Box 82
Brunswick, ME 04011
207-373-0344 (Ph) /207-373-1344 (Fax)

November 21, 2014

Judy George
The Maine Real Estate Network
175 John Roberts Road
South Portland, ME 04106

Dear Judy:

On November 20, 2014, R.J. Enterprises completed the removal of asbestos floor tile, mastic, and linoleum from the house located at 9 Romasco Street in Portland.

The work area was maintained using demolition methods, utilizing critical barriers and negative pressure.

Air sampling conducted at the conclusion of the job indicated an airborne fiber level below the EPA's recommended clearance level of 0.01 fibers per cubic centimeter of air.

All asbestos work was accomplished according to all Federal and State rules and regulations using state-of-the-art equipment and techniques.

If there are any question, please do not hesitate to call.

Sincerely,



Richard F. Giberson