



© 2007 TFH ARCHITECTS

PANEL TYPE R	
1 BED RM #1 RECEPT	2 KITCHEN #1 RECEPT
3 BED RM #2 RECEPT	4 KITCHEN #2 RECEPT
5 LIVING RM RECEPT	6 REFRIDGE
7 DINING RM RECEPT	8 A/C RECEPT
9 RANGE	10 LIGHTING
11 RANGE	12 BATH GFCI
13 WASHER	14 FURNACE
15 DRYER	16 HVAC
17 DRYER	18 HVAC
19 WATERHEATER	20 SMOKE ALARM
21 WATERHEATER	22 STUDY RECEPT
23 SPARE	24 SPARE
25 SPARE	26 SPARE
27 SPARE	28 SPARE
29 SPARE	30 SPARE

PANEL TYPE HP	
1 1ST FLR HALL RECEPT	2 2ND FLR HALL RECEPT
3 3RD FLR HALL RECEPT	4 4TH FLR HALL RECEPT
5 1ST FLR HALL LTS	6 1ST FLR HALL LTS
7 2ND FLR HALL LTS	8 2ND FLR HALL LTS
9 3RD FLR HALL LTS	10 3RD FLR HALL LTS
11 4TH FLR HALL LTS	12 4TH FLR HALL LTS
13 STAIR A LIGHTING	14 STAIR B LIGHTING
15 1ST FLR EL/TEL/SPRINK RECEPT	16 ELEVATOR RM RECEPT
17 ELEVATOR PIT RECEPT	18 2ND FLR MECHANICAL RM RECEPES
19 3RD FLR TEL/DATA RM RECEPT	20 MECHANICAL RM GARAGE LTS
21 PARKING GARAGE LTS	22 PARKING GARAGE LTS
23 1ST FLR LTS TRASH RM ELEVATOR RM	24 4TH FLR TEL/DATA RM RECEPES
25 STORAGE LTS 2ND FLR	26 HEAT PUMP 3<60 AMP>
27 STORAGE LTS 2ND FLR	28 HEAT PUMP 3<60 AMP>
29 ELEVATOR CAB LTS	30 HEAT PUMP 3<60 AMP>
31 HEAT PUMP 1<60 AMP>	32 HEAT PUMP 4<60 AMP>
33 HEAT PUMP 1<60 AMP>	34 HEAT PUMP 4<60 AMP>
35 HEAT PUMP 1<60 AMP>	36 HEAT PUMP 4<60 AMP>
37 HEAT PUMP 2<60 AMP>	38 ELEVATOR <150 AMP>
39 HEAT PUMP 2<60 AMP>	40 ELEVATOR <150 AMP>
41 HEAT PUMP 2<60 AMP>	42 ELEVATOR <150 AMP>

SHERIDAN HEIGHTS
 PROPOSED CONDOMINIUMS AT
 135 SHERIDAN STREET, PORTLAND MAINE
 FOR SHERIDAN STREET LLC



TFH ARCHITECTS
 100 COMMERCIAL STREET
 PORTLAND MAINE 04101
 TELEPHONE 207 775 6141
 ARCHITECTURE PLANNING

CONSULTANTS:
 REFER TO TITLE SHEET FOR
 CONSULTANT INFORMATION

OWNERS' REPRESENTATIVE

477 CONGRESS STREET, 5TH FLOOR
 PORTLAND, ME 04101
 TEL: 207 523 3410

REVISIONS:

DATE: 06/25/07

PROJECT No. 507

DRAWN BY: RTL,RJS

CHECKED BY: TST

SCALE: AS NOTED

SHEET TITLE:
 THIRD
 FLOOR PLAN

E1.5
 Panel Schedule