Portland, Maine



Yes. Life's good here.

September 23, 2015

Doyle Linford &

50 Fairlawn Ave

South Portland, ME 04106

CBL: 013 K057001

Located at 59 CUMBERLAND AVE

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department

AC West Santreas

Fire Prevention Bureau

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager Doyle Linford &				Inspector John Cenate		Inspection Date 9/22/2015
Location 59 CUMBERLAND AVE		CBL 013 K057001		Status		Inspection Type
				Failed		Fire Company-FP Routine Inspec
Code	I !	nt/Ext	Floor	Unit No.	Area	Compliance Date
1) 73.05						
Violation:	NFPA 101- 7.2.1.15.8 FIRE DOOR ASSEMBLY REQ REPAIR; DOOR OPENINGS NOT IN PROPER OPERATING CONDITION SHALL BE REPAIRED OR REPLACED WITHOUT DELAY.					
Notes:	APARTMENT AND BASEMENT DOORS MUST BE FIRE RATED					
2) 55.25						
Violation:	NFPA 101- 31.3.4.5.1 SMOKE ALARMS REQUIRED; In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in accordance with 9.6.2.10, as modified by 31.3.4.5.2, outside every sleeping area in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements.					
Notes:	HARDWIRED SMOKE ALARMS ALL SLEEPING AREAS					
3) 55.511						-
Violation:	NFPA 1, CHAPTER 10 - 10.11.6 HIBACHI OR GRILL ON BALCONY; NO HIBACHI, GAS-FIRED GRILL, CHARCOAL GRILL, OR OTHER SIMILAR DEVICES USED FOR COOKING, HEATING, OROTHER PURPOSE, SHALL BE USED OR KINDLED ON ANY BALCONY OR UNDER ANY OVERHANG PORTION OR WITHIN 10 FTOF ANY STRUCTURE					

Notes:

GAS GRILLS ON PORCHES

Comments:

STATE OF MAINE

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

Linford Doyle & William Boville Defendant

SUMMONS NUMBER:

354906

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 11/09/2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at meserve wordlandmaine.gov to set up an inperson meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 11/09/2015.

Dated: 9/29/15

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Council

City of Portland 389 Congress St Portland, ME 04101

207-874-8480