

... Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
AUBURN, ME 04210
207-784-1507

Job Name : 43 Cumberland Ave.
Drawing : Wood Construction
Location : Portland, ME
Remote Area : Wet
Contract : 4962
Data File : 4th floor calc.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 43 Cumberland Ave. Date - 12/21/12
Location - Portland, ME
Building - Wood Construction System No. - Wet
Contractor - EFP Contract No. - 4962
Calculated By - Robert Peters Drawing No. - 2 of 2
Construction: (x) Combustible () Non-Combustible Ceiling Height varies
OCCUPANCY - residential

S Type of Calculation: ()NFPA 13 Residential (x)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (x)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7 Psi (x) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make Tyco Model LF-II
I Elevation at Highest Outlet - 146.75Feet Size 1/2 K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 57.35 Psi Required 54.52 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 7/16/12 Rated Cap. Cap.
T Time of Test - 12:30 pm @ Psi Elev.
E Static (Psi) - 60 Elev.
R Residual (Psi) - 55 Other Well
Flow (Gpm) - 871 Proof Flow Gpm
S Elevation - 82
P Location: Sheridan St.
P
L Source of Information: Portland Water District
Y

Water Supply Curve (C)


EASTERN FIRE PROTECTION
43 Cumberland Ave.

City Water Supply:

C1 - Static Pressure : 60
C2 - Residual Pressure: 55
C2 - Residual Flow : 871

Demand:

D1 - Elevation : 28.043
D2 - System Flow : 57.352
D2 - System Pressure : 54.523
Hose (Demand) :
D3 - System Demand : 57.352
Safety Margin : 5.444



Fittings Used Summary

EASTERN FIRE PROTECTION
43 Cumberland Ave.

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	60.0	55	871.0	59.967	57.35	54.523

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
LIN	0.0	4.9	7.0	12.96	
4TH	0.0		70.7		
1	146.75	4.85	7.49	13.27	K=K @ DRP
3	146.75	4.85	7.23	13.04	K=K @ DRP
4	146.75	4.85	7.15	12.96	K=K @ DRP
A	146.75		7.63		
B	146.75		7.71		
C	146.75		8.0		
F	146.75		9.33		
2	146.75	4.85	13.9	18.08	K=K @ DRP
D1	146.75		14.29		
D	146.75		14.47		
E	146.75		14.82		
3RD	0.0		70.7		
G	136.75		14.77		
H	136.75		16.85		
P	136.75		19.41		
Q	136.75		20.28		
2ND	0.0		70.7		
I	127.083		21.91		
J	127.083		23.5		
R	127.083		24.62		
S	127.083		25.02		
1ST	0.0		70.7		
K	117.083		28.38		
T	117.083		29.49		
GRND	0.0		70.7		
L	107.083		32.93		
M	107.083		33.29		
N	107.083		34.07		
O	106.753		34.44		
U	107.083		33.87		
V	106.753		34.37		
TOR	106.753		34.64		
BFP	103.0		39.37		
BASE	100.0		46.67		
TEST	82.0		54.52		

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
43 Cumberland Ave.

Page 5
Date 12/21/12

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
LIN to DRP	0 0	4.90	12.96	1	1E	3.825 0.0 3.825	150	7.000 0.0			
			0.0 12.96			0.0 4.825	0.0305	0.147	Vel =	4.37	
DRP			0.0 12.96					7.147	K Factor =	4.85	
1 to C	146.750 146.750	4.85	13.27	1	1T	9.563 0.0 9.562	150	7.490 0.0	K = K @	DRP	
			0.0 13.27			0.0 15.979	0.0319	0.509	Vel =	4.47	
C			0.0 13.27					7.999	K Factor =	4.69	
3 to B	146.750 146.750	4.85	13.04	1	1T	9.563 0.0 9.562	150	7.227 0.0	K = K @	DRP	
			0.0 13.04			0.0 15.645	0.0309	0.483	Vel =	4.39	
B			0.0 13.04					7.710	K Factor =	4.70	
4 to A	146.750 146.750	4.85	12.96	1	1T	9.563 0.0 9.562	150	7.147 0.0	K = K @	DRP	
			0.0 12.96			0.0 15.979	0.0305	0.488	Vel =	4.37	
A to B	146.750 146.750		0.0	1.25		0.0 0.0 7.750	150	7.635 0.0			
			12.96	1.394		0.0 7.750	0.0097	0.075	Vel =	2.72	
B to C	146.750 146.750		13.04	1.25		0.0 0.0 8.250	150	7.710 0.0			
			26.0	1.394		0.0 8.250	0.0350	0.289	Vel =	5.47	
C to F	146.750 146.750		13.27	1.25	1T	9.523 0.0 9.523	150	7.999 0.0			
			39.27	1.394		0.0 17.773	0.0751	1.335	Vel =	8.26	
F to G	146.750 136.750		0.0	1.25	1E	4.762 0.0 4.761	150	9.334 4.331			
			39.27	1.394		0.0 14.761	0.0751	1.109	Vel =	8.26	
G			0.0 39.27					14.774	K Factor =	10.22	
2 to D1	146.750 146.750	4.85	18.08	1	1E	3.825 0.0 3.825	150	13.900 0.0	K = K @	DRP	
			0.0 18.08			0.0 6.825	0.0566	0.386	Vel =	6.09	
D1 to D	146.750 146.750		0.0	1.25	1E	4.762 0.0 4.761	150	14.286 0.0			
			18.08	1.394		0.0 10.511	0.0179	0.188	Vel =	3.80	
D to E	146.750 146.750		0.0	1.25	1E	4.762 0.0 4.761	150	14.474 0.0			
			18.08	1.394	1T	9.523 14.284	0.0178	0.344	Vel =	3.80	
E to P	146.750 136.75		0.0	1.25	1E	4.762 0.0 4.761	150	14.818 4.331			
			18.08	1.394		0.0 14.761	0.0180	0.265	Vel =	3.80	
P			0.0 18.08					19.414	K Factor =	4.10	
G to H	136.750 136.75		39.27	1.5	3T 1E	34.968 5.828 40.796	150	14.774 0.0			
			39.27	1.598		0.0 53.629	0.0386	2.072	Vel =	6.28	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
43 Cumberland Ave.

Page 6
Date 12/21/12

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H to I	136.75 127.083		0.0 39.27	1.5 1.598	1T 0.0	11.656 11.656	150 0.0386	16.846 4.187 0.872			Vel = 6.28
I			0.0 39.27					21.905			K Factor = 8.39
P to Q	136.75 136.750		18.08 18.08	1.25 1.394	1E 3T	4.762 28.57 0.0	150 0.0179	19.414 0.0 0.867			Vel = 3.80
Q to R	136.750 127.083		0.0 18.08	1.5 1.598	1E 0.0	5.828 5.828	150 0.0092	20.281 4.187 0.154			Vel = 2.89
R			0.0 18.08					24.622			K Factor = 3.64
I to J	127.083 127.083		39.27 39.27	1.5 1.61	1E 1T	4.0 8.0 0.0	120 0.0563	21.905 0.0 1.600			Vel = 6.19
J to K	127.083 117.083		0.0 39.27	1.5 1.61		0.0 0.0 9.750	120 0.0563	23.505 4.331 0.549			Vel = 6.19
K			0.0 39.27					28.385			K Factor = 7.37
R to S	127.083 127.083		18.08 18.08	1.5 1.61	4E 0.0	16.0 0.0 16.000	120 0.0134	24.622 0.0 0.402			Vel = 2.85
S to T	127.083 117.083		0.0 18.08	1.5 1.61		0.0 0.0 9.750	120 0.0134	25.024 4.331 0.131			Vel = 2.85
T			0.0 18.08					29.486			K Factor = 3.33
K to L	117.083 107.083		39.27 39.27	2 2.157	1E 0.0	6.153 0.0 6.153	120 0.0136	28.385 4.331 0.219			Vel = 3.45
L			0.0 39.27					32.935			K Factor = 6.84
T to U	117.083 107.083		18.08 18.08	2 2.157	1E 0.0	6.153 0.0 6.153	120 0.0032	29.486 4.331 0.052			Vel = 1.59
U			0.0 18.08					33.869			K Factor = 3.11
L to M	107.083 107.083		39.27 39.27	2 2.157	1E 1T	6.153 12.307 0.0	120 0.0135	32.935 0.0 0.351			Vel = 3.45
M to N	107.083 107.083		0.0 39.27	2 2.157	2E 1T	12.307 12.307 0.0	120 0.0136	33.286 0.0 0.781			Vel = 3.45
N to O	107.083 106.753		0.0 39.27	2 2.157	1T 0.0	12.307 0.0 17.307	120 0.0135	34.067 0.143 0.234			Vel = 3.45

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
43 Cumberland Ave.

Page 7
Date 12/21/12

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pf Pe Pf	*****	Notes	*****
O to TOR	106.753 106.753		18.08 57.35	2	1E 0.0 0.0	6.153 6.153 7.153	120 0.0274	34.444 0.0 0.196		Vel = 5.04	
TOR			0.0 57.35					34.640		K Factor = 9.74	
U to V	107.083 106.753		18.08 18.08	2	3T 4E 0.0	36.92 24.613 110.533	120 0.0032	33.869 0.143 0.356		Vel = 1.59	
V to O	106.753 106.753		0.0 18.08	2	1E 1T 0.0	6.153 12.307 23.543	120 0.0032	34.368 0.0 0.076		Vel = 1.59	
O			0.0 18.08					34.444		K Factor = 3.08	
TOR to BFP	106.753 103		57.35 57.35	2	1Fsp 0.0 0.0	3.000 0.0 3.000	120 0.0337	34.640 4.625 0.101		* Fixed loss = 3 Vel = 5.48	
BFP to BASE	103 100		0.0 57.35	2	1Zaa 1E 0.0	0.0 5.0 8.167	120 0.0335	39.366 7.027 0.274		* Fixed loss = 5.728 Vel = 5.48	
BASE to TEST	100 82		0.0 57.35	4	1E 1T 1G	14.534 29.067 2.907	140 0.0009	46.667 7.796 0.060		Vel = 1.39	
TEST			0.0 57.35					54.523		K Factor = 7.77	