Structural Integrity
Consulting Engineers, Inc.
77 Oak Street, Portland, ME 04101 | p. 207-774-4614 | f. 866-793-7835

Date: _____ Page: __
By: _____ Chkd by: .
Project: _____
Job #: _____

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/14/17

GALV. L6×3½×5/16 w/ (4) 5/8"Ø THRU BOLTS @ EA. CLIP, THRU (N) LEDGER AND (E) RIM. VERIFY (E) RIM IN FIELD IS MIN. 1½" THICK FULL HEIGHT.

B/4

C/4

TYP. STEEL CONNECTIONS