S.I. 1/5/17

ALL EXPOSED STEEL HOT-DIP GALVANIZED

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/14/17

VERIFY (E) RIM IS MIN. 1½" THICK AND FULL DEPTH IN FIELD -TYP.

GALV. L3½x3½x¼x6" W/ (3) 3/8"x4" RSS SCREWS THRU CLIP, LEDGER, AND (E) RIM, EA. SIDE OF (N) STL. BM.

(E) RIM

(N) JOIST FASTENED TO (E) RIM

ANGLE ATTACHMENT (TYP)

(2) 3/4"Ø BOLTS THRU ANGLE CLIPS AND BM. WEB

DTT1Z FASTENED TO JOIST @ MIDSPAN OF STL. BM., W/ 3/8"Ø GALV. BOLT THRU, DTT1Z, P.T. WEB PACKING, AND STL. BM. WEB

LAST JOIST FASTENED TO (E) RIM JOIST W/ MIN. (2) 10d @ 16" O.C.

P.T. 2x8 LEDGER FASTENED TO (E) RIM JOIST W/ (2) ¼"Ø x 3½" RSS SCREWS @ 16" O.C.

FASTENING PER PLAN

GALV. STL. BM. PER PLAN

GALV. HSS4x4x3/16 ABOVE -TYP.

DTT2Z, SEE H/7

JOISTS @ 12" O.C. IF COMPOSITE DECKING IS USED - TYP.

P.T. 2x8 @ 16" O.C.

HANGER TO P.T. WEB PACKING -TYP.

2X FRAMING

COLUMN TO 3RD FLOOR

COLUMN TO 2ND FLOOR

GALV. W8x10

LUS 28-Z -TYP.

DTT2Z, SEE H/7

DECK ABOVE

STEEL TUBE (TYP)

WIDE FLANGE BEAMS

STEEL COLUMN

GALV. W8x10

GALV. W8x10

(4) RSS SCREWS IN LEDGER @ BM. CONNECTION

G/6

(3) ¼"Ø TIMBERLOKS THRU JOISTS, FULLY EMBEDDED INTO P.T. WEB PACKING @ ACUTE JOIST ANGLE TO BEAM

(E) FRAMING

FLASHING PER ARCH-TYP.

TYP. STL. BM. TO (E) RIM

FIRST FLOOR FRAMING

4 / A1.0

0 4'-0"

SCALE: 1/4" = 1'-0"

1/8