

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that RICHARD J& HAYES

Located At 62 CUMBERLAND AVE

Job ID: 2011-03-536-UI


CBL: 013 - - L - 002 - 001 - - - -

has permission to install a supervised, automatic sprinkler system.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be


Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY.
PENALTY FOR REMOVING THIS CAR



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Director of Planning and Urban Development
Penny St. Louis

Job ID: 2011-03-536-UI

Located At: 62 CUMBERLAND

CBL: 013 - - L - 002 - 001 - - - -

Conditions of Approval:

Zoning

1. This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.
2. This property shall remain a three family dwelling. Any change of use shall require a separate permit application for review and approval.

Fire

A State Permit is required.

The sprinkler system shall be installed in accordance with NFPA 13R. The basement parking garage shall be designed in accordance with NFPA 13.

Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.

The Fire Department will require Knox locking caps on all Fire Department Connections on the exterior of the building.

Installation of a sprinkler or fire alarm system requires a Knox Box to be installed per city ordinance.

The sprinkler system shall be supervised by Central Station. The FACP/DACT shall be protected by a smoke detector and one manual pull station shall be located inside the front door. A separate Fire Alarm Permit is required. All fire alarm installation and servicing companies shall have a Certificate of Fitness from the Fire Department.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.



Water-Based Fire Suppression System Permit

795 Kelly 6314
Will send electronic plans by email

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Taxes ok

Installation address: 62 CUMBERLAND AVE CBL: 013 L 002

Exact location: (within structure) ENTIRE BLDG

Type of occupancy(s) (NFPA & ICC): NFPA 13R APARTMENT/CONDO

Building owner: PAUL LEDMAN

Managing Supervisor (RMS): WILLIAM FLYNT License No: 368

Supervisor phone: 784-1507 E-mail: FLYNTWA@TEAMEASTERN.COM

Installing contractor: EASTERN FIRE PROT. License No: 101

Contractor phone: 784-1507 E-mail: _____

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO Permit no: _____

NFPA Standard this system is designed to: NFPA 13R Edition: _____

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from www.portlandmaine.gov/fire for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

COST OF WORK: \$12,000
PERMIT FEE: \$150.00
 (\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

RECEIVED
 APR - 4 2011
By mail

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315 Portland, Maine 04104

**Dept of Building Inspections
City of Portland Maine**

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: [Signature] Date: 3/31/11



EASTERN FIRE PROTECTION

P.O. Box 1390
Kittyhawk Ave.
Auburn, ME 04210

PH # (207) 784-1507
FAX # (207) 782-0566

LETTER OF TRANSMITTAL

DATE	3/31/11	JOB NO.	AN-4634-10
ATTENTION	LANNIE DOBSON		
RE:	62 CUMBERLAND AVE.		

TO CITY OF PORTLAND
BLDG INSPECTION DEPT
389 CONGRESS ST., PORTLAND, ME
04101

WE ARE SENDING YOU Attached Under separate cover via _____ the following items:
 Shop drawings Descriptive data Hydraulic calculations
 Copy of letter Literature _____

QUANTITY	DRAWING NO.	DATE	DESCRIPTION	STATUS
1	10F1	3/29/11	FIRE SPRINKLER SYSTEM PLAN 30x42	C
1	10F1	3/29/11	" " " " 11x17	
1		3/29	HYD CALCULATIONS AREA#1 / AREA#2	C
1		3/31	PERMIT APPLICATION	
1		3/31	CHECK \$150.00 PERMIT FEE	

Status code A. Approved D. Corrected & resubmitted
 B. Approved as noted E. For your files
 C. Submitted for approval F. Refer to remarks

Please return 1 copies each indicating your approval and/or comments.

PERMIT

RECEIVED

APR - 1 2011

Dept. of Building Inspections
City of Portland Maine

REMARKS _____

COPY TO _____

SIGNED *[Signature]*

Job Summary Report
Job ID: 2011-03-536-UI

Report generated on Apr 4, 2011 2:57:19 PM

Fee Code Description	Charge Amount	Permit Charge Adjustment	Permit Charge Adj Remark	Payment Date	Receipt Number	Payment Amount	Payment Adjustment Amount	Payment Adj Comment
Electric Commercial Permit Fee	\$55.00			3/7/11	1698	\$55.00		

X **Permit #: 20112421**

Permit Data						
Location Id	Structure Description	Permit Status	Permit Description	Issue Date	Reissue Date	Expiration Date
1610	3- unit residential 1 owner occ 2 rental	Initialized	Water-based fire suppression system			

Inspection Details						
Inspection Id	Inspection Type	Inspection Result Status	Inspection Status Date	Scheduled Start Timestamp	Result Status Date	Final Inspection Flag

Fees Details								
Fee Code Description	Charge Amount	Permit Charge Adjustment	Permit Charge Adj Remark	Payment Date	Receipt Number	Payment Amount	Payment Adjustment Amount	Payment Adj Comment
Job Valuation Permit Based Fee	\$140.00							

4/4/11

Job Summary Report
Job ID: 2011-03-536-UI

Report generated on Apr 4, 2011 2:57:19 PM

Job Type:	UI - Building Permit	Job Description:	62 Cumberland UI Permit#10119	Job Year:	2011
Building Job Status Code:	Permit Issued	Pin Value:	801	Tenant Name:	
Job Application Date:		Public Building Flag:	N	Tenant Number:	
Estimated Value:		Square Footage:			
Related Parties:		RICHARD J HAYES		<i>Property Owner</i>	
		BAUMAN Electric - ROBERT BAUMAN		<i>ELECTRICAL CONTRACTOR</i>	
		Eastern Fire Protection Co.,Inc - Eastern Fire Protection Co.,Inc		<i>SPRINKLER CONTRACTOR</i>	
		Island Carpentry Inc - Mike White		<i>GENERAL CONTRACTOR</i>	

Job Charges

Fee Code Description	Charge Amount	Permit Charge Adjustment	Net Charge Amount	Payment Date	Receipt Number	Payment Amount	Payment Adjustment Amount	Net Payment Amount	Outstanding Balance
----------------------	---------------	--------------------------	-------------------	--------------	----------------	----------------	---------------------------	--------------------	---------------------

Location ID: 1610

Location Details

Alternate Id	Parcel Number	Census Tract	GIS X	GIS Y	GIS Z	GIS Reference	Longitude	Latitude
R11269	013 L 002 001		M				-70.249607	43.665169

Location Type	Subdivision Code	Subdivision Sub Code	Related Persons	Address(es)
1				62 CUMBERLAND AVENUE NORTH

Location Use Code	Variance Code	Use Zone Code	Fire Zone Code	Inside Outside Code	District Code	General Location Code	Inspection Area Code	Jurisdiction Code
VACANT LAND		NOT APPLICABLE	<i>(B-3)</i>	<i>R-1</i>			DISTRICT 1	EAST END

Structure Details

Structure: 3- unit residential 1 owner occ 2 rental

Occupancy Type Code:

Structure Type Code	Structure Status Type	Square Footage	Estimated Value	Address
Three - Four Family Building	0			62 CUMBERLAND AVENUE NORTH

Longitude	Latitude	GIS X	GIS Y	GIS Z	GIS Reference	User Defined Property	Value
						Dryers	1
						Fixtures-Incandescent	1
						Fixtures-Incandescent	5

Hayes

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov


With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

1. A final inspection shall be coordinated between sprinkler and fire alarm contractors and the fire department.

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



... Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
AUBURN, ME 04210
207-784-1507

Job Name : 62 CUMBERLAND AVE
Building : APARTMENT / CONDO
Location : PORTLAND
System : 1 OF 1
Contract : AN-4634-10
Data File : AREA#2 3RD FLOOR.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 62 CUMBERLAND AVE Date - 3-28-11
Location - PORTLAND
Building - APARTMENT / CONDO System No. - 1 OF 1
Contractor - EASTERN FIRE PROTECTION Contract No. - AN-4634-10
Calculated By - GRD Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-0"
OCCUPANCY - RESIDENTIAL DWELLING UNIT

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 16 Gpm System Type
Listed Pres. at Start Point - 13.2 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII 2334
I Elevation at Highest Outlet - 135.5Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 67.042 Psi Required 52.681 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 8-16-07 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 60 Elev.
R Residual (Psi) - 24 Other Well
Flow (Gpm) - 1254 Proof Flow Gpm
S Elevation - 100
P Location: SEE PLOT PLAN
P
L Source of Information: PORTLAND WATER DISTRICT
Y


Water Supply Curve (C)

EASTERN FIRE PROTECTION
62 CUMBERLAND AVE

Page 2
Date

City Water Supply:
C1 - Static Pressure : 60
C2 - Residual Pressure: 24
C2 - Residual Flow : 1254

Demand:
D1 - Elevation : 15.375
D2 - System Flow : 67.042
D2 - System Pressure : 52.681
Hose (Demand) :
D3 - System Demand : 67.042
Safety Margin : 7.159



Fittings Used Summary

EASTERN FIRE PROTECTION
62 CUMBERLAND AVE

Page 3
Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120	
N*	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0	
O*	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	60.0	24	1254.0	59.84	67.04	52.681

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
DP01	7.17	5.6	11.76	19.2	
EQ01	8.17		11.44		
DP02	7.17	5.6	11.76	19.2	
EQ02	8.17		12.05		
300	135.5	4.4	13.24	16.01	
303	135.5	4.4	13.2	15.99	
301	135.5	4.4	14.86	16.96	
250	127.0		18.12		
251	127.0		20.83		
302	135.5	4.4	16.89	18.08	
252	127.0		22.84		
149	117.5		27.32		
150	117.75		27.26		
151	117.75		31.52		
152	107.0		38.15		
153	107.0		39.67		
TOR	107.0		40.28		
BASE	100.0		52.57		
UG1	100.0		52.66		
TEST	100.0		52.68		

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
62 CUMBERLAND AVE

Page 5
Date


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP01 to EQ01	7.17 8.17	5.60	19.20 19.2	1 1.049		0.0 0.0	1.000 0.0	120 0.1210	11.755 -0.433 0.121			Vel = 7.13
EQ01			0.0 19.20						11.443			K Factor = 5.68
DP02 to EQ02	7.17 8.17	5.60	19.20 19.2	1 1.049	1T	5.0 0.0	1.000 5.000	120 0.1207	11.755 -0.433 0.724			Vel = 7.13
EQ02			0.0 19.20						12.046			K Factor = 5.53
300 to 250	135.500 127	4.40	16.01 16.01	1 1.101	1N 1O	7.0 5.0	14.500 12.000	150 0.0451	13.242 3.681 1.195			Vel = 5.40
250			0.0 16.01						18.118			K Factor = 3.76
303 to 250	135.500 127	4.40	15.99 15.99	1 1.101	1N 1O	7.0 5.0	15.500 12.000	150 0.0450	13.200 3.681 1.237			Vel = 5.39
250			0.0 15.99						18.118			K Factor = 3.76
301 to 251	135.500 127	4.40	16.96 16.96	1 1.101	3N 2O	21.0 10.0	14.500 31.000	150 0.0502	14.862 3.681 2.284			Vel = 5.72
251			0.0 16.96						20.827			K Factor = 3.72
250 to 251	127 127		32.00 32.0	1.25 1.394	4N 1O	32.0 6.0	14.667 38.000	150 0.0514	18.118 0.0 2.709			Vel = 6.73
251 to 150	127 117.750		16.96 48.96	1.5 1.598	1N 1O	9.0 8.0	24.750 17.000	150 0.0581	20.827 4.006 2.425			Vel = 7.83
150			0.0 48.96						27.258			K Factor = 9.38
302 to 252	135.500 127	4.40	18.08 18.08	1 1.101	2N 2O	14.0 10.0	16.250 24.000	150 0.0565	16.888 3.681 2.273			Vel = 6.09
252 to 149	127 117.500		0.0 18.08	1.5 1.598	1N 1O	9.0 8.0	23.000 17.000	150 0.0092	22.842 4.114 0.368			Vel = 2.89
149 to 150	117.500 117.750		0.0 18.08	1.5 1.598		0.0 0.0	4.625 0.0	150 0.0091	27.324 -0.108 0.042			Vel = 2.89
150 to 151	117.750 117.750		48.96 67.04	1.5 1.598	1N 1O	9.0 8.0	24.000 17.000	150 0.1039	27.258 0.0 4.261			Vel = 10.72

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
62 CUMBERLAND AVE

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
151 to 152	117.750 107		0.0 67.04	1.5 1.598	1N	9.0 0.0	10.000 9.000	150	31.519 4.656			
						0.0	19.000	0.1039	1.974	Vel = 10.72		
152 to 153	107 107		0.0 67.04	2	3E 1T	15.0 10.0	9.000 25.000	120	38.149 0.0			
						0.0	34.000	0.0449	1.525	Vel = 6.41		
153 to TOR	107 107		0.0 67.04	2	1I 1J	4.307 10.461	2.000 14.768	120	39.674 0.0			
						0.0	16.768	0.0364	0.611	Vel = 5.89		
TOR to BASE	107 100		0.0 67.04	2	1Fsp	0.0 0.0	7.000 0.0	120	40.285 12.032		* Fixed loss = 9	
						0.0	7.000	0.0364	0.255	Vel = 5.89		
BASE to UG1	100 100		0.0 67.04	4	1E 1T	14.534 29.067	25.000 46.508	140	52.572 0.0			
						2.907	71.508	0.0012	0.085	Vel = 1.63		
UG1 to TEST	100 100		0.0 67.04	6	1T	43.037 0.0	100.000 43.037	140	52.657 0.0			
						0.0	143.037	0.0002	0.024	Vel = 0.72		
TEST			0.0 67.04						52.681	K Factor = 9.24		



... **Fire Protection by Computer Design**

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
AUBURN, ME 04210
207-784-1507

Job Name : 62 CUMBERLAND AVE
Building : APARTMENT/ CONDO
Location : PORTLAND, MAINE
System : 1 OF 1
Contract : AU-4634-10
Data File : AREA#1 BASEMENT.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 62 CUMBERLAND AVE Date - 3-29-11
Location - PORTLAND, MAINE
Building - APARTMENT/ CONDO System No. - 1 OF 1
Contractor - EASTERN FIRE PROTECTION Contract No. - AU-4634-10
Calculated By - GRD Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'
OCCUPANCY - DWELLING UNIT GARAGE

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO LFII Model PENDENT
I Elevation at Highest Outlet - 108.00Feet Size 1/2" K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 53.396 Psi Required 36.885 At Test
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 8-16-07 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 60 Elev.
R Residual (Psi) - 24 Other Well
Flow (Gpm) - 1254 Proof Flow Gpm
S Elevation - 100
P Location: SEE PLOT PLAN
P
L Source of Information: PORTLAND WATER DISTRICT
Y


Water Supply Curve (C)

EASTERN FIRE PROTECTION
62 CUMBERLAND AVE

Page 2
Date

City Water Supply:
C1 - Static Pressure : 60
C2 - Residual Pressure: 24
C2 - Residual Flow : 1254

Demand:
D1 - Elevation : 3.465
D2 - System Flow : 53.396
D2 - System Pressure : 36.885
Hose (Demand) :
D3 - System Demand : 53.396
Safety Margin : 23.010



Fittings Used Summary

EASTERN FIRE PROTECTION
62 CUMBERLAND AVE

Page 3
Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	
N*	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0	
O*	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0	
S	NFPA 13 Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	60.0	24	1254.0	59.895	53.4	36.885

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
DP01	0.0	4.9	7.0	12.96	
DP02	0.0	4.9	7.0	12.96	
100	108.0	4.82	7.24	12.96	K=K @ EQ01
101	108.0	4.82	7.61	13.29	K=K @ EQ01
50	108.0		9.19		
51	108.0		11.56		
52	108.0		12.46		
102	108.0	4.82	7.68	13.35	K=K @ EQ01
103	108.0	4.84	8.13	13.79	K=K @ EQ02
53	108.0		9.57		
54	108.0		11.6		
55	108.0		12.56		
AFL	108.0		23.3		
TOR	108.0		24.14		
BASE	100.0		36.81		
UG1	100.0		36.87		
TEST	100.0		36.88		

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
62 CUMBERLAND AVE

Page 5
Date



Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP01 to EQ01	0 0	4.90	12.96 12.96	1 1.101	1N	7.0 0.0	1.000 7.000	150	7.000 0.0			
			0.0			0.0	8.000	0.0305	0.244	Vel =	4.37	
EQ01			12.96						7.244	K Factor =	4.82	
DP02 to EQ02	0 0	4.90	12.96 12.96	1 1.101	1O	5.0 0.0	1.000 5.000	150	7.000 0.0			
			0.0			0.0	6.000	0.0305	0.183	Vel =	4.37	
EQ02			12.96						7.183	K Factor =	4.84	
100 to 101	108 108	4.82	12.96 12.96	1 1.101		0.0 0.0	12.000 0.0	150	7.244 0.0	K = K @	EQ01	
						0.0	12.000	0.0305	0.366	Vel =	4.37	
101 to 50	108 108	4.82	13.29 26.25	1 1.101		0.0 0.0	14.000 14.000	150	7.610 1.576	K = K @	EQ01	
						0.0	14.000	0.1126	1.576	Vel =	8.85	
50 to 51	108 108		0.0 26.25	1.25 1.394	4N	32.0 0.0	34.500 32.000	150	9.186 0.0			
						0.0	66.500	0.0357	2.372	Vel =	5.52	
51 to 52	108 108		0.0 26.25	1.25 1.38	2E 1T	6.0 6.0	4.000 12.000	120	11.558 0.0			
						0.0	16.000	0.0566	0.905	Vel =	5.63	
52 to 55	108 108		0.0 26.25	1.25 1.38		0.0 0.0	1.750 1.750	120	12.463 0.0			
						0.0	1.750	0.0566	0.099	Vel =	5.63	
55			0.0 26.25						12.562	K Factor =	7.41	
102 to 103	108 108	4.82	13.35 13.35	1 1.101		0.0 0.0	14.000 0.0	150	7.681 0.0	K = K @	EQ01	
						0.0	14.000	0.0322	0.451	Vel =	4.50	
103 to 53	108 108	4.84	13.79 27.14	1 1.101		0.0 0.0	12.000 12.000	150	8.132 1.437	K = K @	EQ02	
						0.0	12.000	0.1198	1.437	Vel =	9.15	
53 to 54	108 108		0.0 27.14	1.25 1.394	2N	16.0 0.0	37.500 16.000	150	9.569 0.0			
						0.0	53.500	0.0379	2.030	Vel =	5.71	
54 to 55	108 108		0.0 27.14	1.25 1.38	2E 1T	6.0 6.0	4.000 12.000	120	11.599 0.0			
						0.0	16.000	0.0602	0.963	Vel =	5.82	
55 to AFL	108 108		26.26 53.4	1.25 1.38	2E 2S	6.0 14.0	19.000 51.000	120	12.562 10.738			
						12.0	32.000		0.0	Vel =	11.45	
AFL to TOR	108 108		0.0 53.4	1.25 1.38	1I	3.0 0.0	1.000 3.000	120	23.300 0.0			
						0.0	4.000	0.2105	0.842	Vel =	11.45	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
62 CUMBERLAND AVE

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
TOR to BASE	108 100		0.0 53.4	2 2.067	1Fsp	0.0 0.0 0.0	7.000 0.0 7.000	120 0.0294	24.142 12.465 0.206		* Fixed loss = 9 Vel = 5.11	
BASE to UG1	100 100		0.0 53.4	4 4.1	1E 1T 1G	14.534 29.067 2.907	25.000 46.508 71.508	140 0.0008	36.813 0.0 0.056		Vel = 1.30	
UG1 to TEST	100 100		0.0 53.4	6 6.16	1T	43.037 0.0 0.0	100.000 43.037 143.037	140 0.0001	36.869 0.0 0.016		Vel = 0.57	
TEST			0.0 53.40						36.885		K Factor = 8.79	





FIRE SPRINKLER PLAN - THIRD FLOOR

SCALE: 1/8"=1'-0"
 AREA PROTECTED: 770 SQ.FT.
 FINISH FLOOR ELEVATION : 128.083'
 COLOR CODE:

Symbol	Count	Thread	K-Factor	Description	Note
◁	10	1/2"	4.4	TYCO LFI WHITE HORIZ SIDEWALL TY2334	
10 = Total Number of Heads THIRD FLOOR					

Symbol	Count	Thread	K-Factor	Description	Note
●	13	1/2"	4.8	TYCO LFI WHITE RECESSED PENDENT TY2234	ON DROP
13 = Total Number of Heads FIRST FLOOR					





FIRE SPRINKLER PLAN - SECOND FLOOR

SCALE: 1/8"=1'-0"
 AREA PROTECTED: 1745 SQ.FT.
 FINISH FLOOR ELEVATION : 118.083'
 COLOR CODE:

Symbol	Count	Thread	K-Factor	Description	Note
●	7	1/2"	4.8	TYCO LFI WHITE RECESSED PENDENT TY2234	ON DROP
◁	8	1/2"	4.4	TYCO LFI WHITE HORIZ SIDEWALL TY2334	
13 = Total Number of Heads SECOND FLOOR					

Symbol	Count	Thread	K-Factor	Description	Note
●	11	1/2"	4.8	TYCO LFI WHITE RECESSED PENDENT TY2234	ON DROP
○	2	1/2"	5.6	TYCO TY-FIBR BRASS UPRIGHT TY-3131	ON LINE
●	3	1/2"	5.6	TYCO TY-FIBR WHITE RECESSED PENDENT TY-3233	ON DROP
16 = Total Number of Heads BASEMENT					



Maximum Coverage Area (ft. x ft.) (m x m)	Maximum Spacing (ft.) (m)	Minimum Flow (l/min) and Residual Pressure For Horizontal Ceiling (Head: 2 to 4 ft. Rise Not to Exceed 4 ft. (1.2 m))		Minimum Flow (l/min) and Residual Pressure For Recessed Ceiling (Head: 2 to 4 ft. Rise Not to Exceed 4 ft. (1.2 m))	
		150°F/54°C	170°F/77°C	150°F/54°C	170°F/77°C
11 x 13 (3.3 x 4.0)	11 (3.3)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
11 x 18 (3.3 x 5.5)	13 (4.0)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
11 x 24 (3.3 x 7.3)	15 (4.6)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
11 x 30 (3.3 x 9.1)	17 (5.2)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
11 x 36 (3.3 x 10.9)	19 (5.8)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	13 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)


Maximum Coverage Area (ft. x Length) (ft. x m)	Minimum Spacing (ft.) (m)	Minimum Flow (l/min) and Residual Pressure	
		Top-Of-Obstruction To Ceiling (4 to 8 in. (102 to 203 mm))	Top-Of-Obstruction To Ceiling (4 to 12 in. (102 to 305 mm))
10 x 10 (3.0 x 3.0)	10 (3.0)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
10 x 15 (3.0 x 4.5)	12 (3.7)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
10 x 20 (3.0 x 6.0)	14 (4.3)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
10 x 25 (3.0 x 7.5)	16 (4.9)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
10 x 30 (3.0 x 9.0)	18 (5.5)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
10 x 35 (3.0 x 10.5)	20 (6.1)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
10 x 40 (3.0 x 12.0)	22 (6.7)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
10 x 45 (3.0 x 13.5)	24 (7.3)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)
10 x 50 (3.0 x 15.0)	26 (7.9)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)	15 GPM @ 2.0 LPM (7.6 psi @ 0.88 bar)

GENERAL NOTES
 SPRINKLER SYSTEM INSTALLATION TO COMPLY WITH NFPA PAMPHLET # 13R, 2007 EDITION.
 OCCUPANCY DESCRIPTION AND CLASSIFICATION: APARTMENT DWELLING UNITS, CORRIDORS - LIGHT HAZARD BASEMENT MECH RM - ORDINARY HAZARD GROUP I

ALL DIMENSIONS ARE SHOWN FOR GENERAL LOCATION OF SPRINKLER HEADS, PIPING MAY VARY TO SUIT ACTUAL FIELD CONDITIONS.
 STORAGE OF MATERIAL SHALL NOT EXCEED 8'-0" IN HEIGHT.
 ALL WIRING TO BE DONE BY OTHERS
 ○ = INDICATES HYDRULIC REFERENCE POINTS.
 FT. CL. = FINISH FLOOR PL. TO CENTERLINE OF PIPE.
 SJ. CL. = BOTTOM OF JOIST DOWN TO CENTERLINE OF PIPE.
 TL. CL. = TOP OF JOIST DOWN TO CENTERLINE OF PIPE.

PIPE SIZE	Ambient Temperature During Cure Period		
	80°F to 120°F	40°F to 50°F	0°F to 30°F
3/4"	45 min.	1.5 hr.	24 hr.
1"	45 min.	1.5 hr.	24 hr.
1-1/4"	1.5 hr.	1.6 hr.	120 hr.
1-1/2"	1.5 hr.	1.6 hr.	120 hr.
2"	6 hr.	36 hr.	See Note 1
2-1/2"	6 hr.	72 hr.	See Note 1
3"	8 hr.	72 hr.	See Note 1

Note 1: For these sizes, the solvent cement can be applied at temperatures below 40°F, however, the sprinkler system temperature must be raised to a temperature of 40°F or above and allowed to cure per the above recommendations prior to pressure testing.



CPVC SPRINKLER HEAD INSTALLATION DETAIL
 NOT TO SCALE
 Thread the sprinkler into the adapter fitting only. Do not pre-assemble the drop assembly with the sprinkler head prior to cementing all joints.
 USE "DATEY" GREAT WHITE PIPE JOINT COMPOUND OR TEFLON TAPE ON ALL STEEL OR BRASS PIPE THREADS.