

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

CONGRESS 135 MARKET LLC

Located at

135 CONGRESS ST

PERMIT ID: 2015-01452

ISSUE DATE: 07/28/2015

CBL: 013 L022001

has permission to **Relocation of the mua fan and exhaust fan (kitchen exhaust system) to the lower part of the roof.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

1st floor retail, three dwelling units above

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01452	Date Applied For: 06/19/2015	CBL: 013 L022001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Retail - First Floor with three (3) dwelling units above.		Proposed Project Description: Relocation of the mua fan and exhaust fan (kitchen exhaust system to the lower part of the roof.		
Dept: Zoning	Status: Approved	Reviewer: Ann Machado	Approval Date: 06/30/2015	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
Dept: Engineering DPS	Status: Not Applicable	Reviewer: Benjamin Pearson	Approval Date: 06/29/2015	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 07/02/2015	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Hood suppression system shall comply with NFPA 17A, 96, and UL 300. Activation of the suppression system shall activate the fire alarm system if available. A letter of compliance will be required at the time of final inspection stating: the date the system was tested for operation, fuel gas shut off, and fire alarm connection if applicable. The Class K fire extinguisher and proper signage should be located at the suppression system pull station.				
2) Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 31, Standard for the Installation of Oil-Burning Equipment; NFPA 54, National Fuel Gas Code; NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems; NFPA 91, Standard for Exhaust Systems for Air Conveying Vapors, Gases, Mists, and Noncombustible Particulate Solids; NFPA 70, National Electrical Code; and the manufacturer's published instructions.				
3) All construction shall comply with City Code Chapter 10.				