



- FACP FIRE ALARM CONTROL PANEL, MOUNT WITH TOP OF PANEL NOT MORE THAN 72" AFF
- FAA FIRE ALARM ANNUCIATOR, MOUNT WITH TOP OF PANEL NOT MORE THAN 72" AFF
- S SMOKE DETECTOR
- H HEAT DETECTOR
- DS DUCT SMOKE DETECTOR
- RTS REMOTE TEST INDICATOR FOR DUCT SMOKE, MOUNT ON CEILING BENEATH UNIT, OR WALL MOUNT WHERE INDICATED ON PLANS
- SRLV SUPPRESSOR RELAY FOR HOOD
- P MANUAL PULL STATION, MOUNT 48" AFF
- H MINI HORN - MOUNT 80" AFF TO BOTTOM OR 6" BELOW CEILING WHICHEVER IS LOWER.
- H HORN/STROBE APPLIANCE, 15 CANDELA OR AS NOTED ON PLANS, MOUNT 80" AFF TO BOTTOM OR 6" BELOW CEILING WHICHEVER IS LOWER  
 'C' INDICATES CEILING MOUNTED UNIT  
 'E' INDICATES EXTERIOR RATED UNIT
- V VISUAL INDICATING APPLIANCE, 15 CANDELA OR AS NOTED ON PLANS, MOUNT 80" AFF TO BOTTOM OR 6" BELOW CEILING WHICHEVER IS LOWER  
 'C' INDICATES CEILING MOUNTED UNIT  
 'E' INDICATES EXTERIOR RATED UNIT
- W SPRINKLER SYSTEM WATER FLOW SWITCH
- T SPRINKLER SYSTEM TAMPER SWITCH
- K KNOX BOX, MOUNT AT LOCATION ACCEPTABLE TO AHJ

2 FIRE ALARM LEGEND

1 FIRE ALARM PLAN ~ BASEMENT  
 SCALE: 1/4" = 1'-0"

FIRE DEPARTMENT STAMP

REVISIONS	NUMBER	DATE	BY	DESCRIPTION
Date: 11/JUN/2014 (24X26)				
Drawn By: CRH				
Checked By: TP				
Project Mgr: TP				
Project No: CHS				
Cod File: CHS-FA-PLANS.DWG				
Graphic Scale: 0 1"				

FIRE ALARM PLAN  
 BASEMENT  
 COLUCCI'S HILLTOP SUPERETTE  
 135 CONGRESS ST  
 PORTLAND, MAINE  
 © copyright 2014 CONNECTIVITY POINT LLC