

# Fire System Sequence of Operations

Actuation	Action							
	Audio visual activation FACP & Ann	Device Desc. At FACP & Ann	Shutdown of HVAC Equip.	Log Events in System History	Silencing of Audible devices including FACP & Ann	Event Acknowledgement	Reset all system functions and visual devices	Station A-Alarm S-Supervisory L-Log T-Trouble
Smoke Detectors in common area	X		X					A
Duct installed smoke detectors	X	X	X					S
Sprinkler flow switches	X		X					A
Sprinkler tamper switch	X		X					S
FACP/annunciator silence button	X		X		X			L
FACP/annunciator acknowledge button	X		X					
FACP/annunciator reset button	X		X			X		L
Device Removals	X		X					T
Ground Faults	X		X					T
System wiring open	X		X					T
Power Loss	X		X					T
Back-up power loss	X		X					T
Communication Loss	X		X					T
Manual Pull Stations	X	X	X					A