



April 19, 2016

Genovese Rocco D &

56 Cornell St

South Portland , ME 04106

CBL: 013 M013001

Located at 0072 CUMBERLAND AVE

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Capt. D. Petrucci

Portland Fire Department

Fire Prevention Bureau

CITY OF PORTLAND
PORTLAND FIRE DEPARTMENT

380 Congress Street
Portland, Maine 04101

353699

Inspection Violations

Owner/Manager Genovese Rocco D &		Inspector John Cenate	Inspection Date 4/15/2016
Location 0072 CUMBERLAND AV	CBL 013 M013001	Status Failed	Inspection Type Fire Prevention-FP Routine Inspe

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 3.011

Violation: NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED; THE AREAS DESCRIBED IN TABLE 31.3.2.1.1 SHALL BE PROTECTED AS INDICATED:
BOILER AND FUEL-FIRED HEATER ROOMS SERVING MORE THAN A SINGLE DWELLING UNIT
(MINIMUM SEPARATION/PROTECTION IS 1 HOUR OR SPRINKLERS)

Notes:

2) 80.37

Violation: NFPA 101- 8.3.4.2 60 MINUTE FIRE DOOR REQUIRED; REFER TO NFPA 101- TABLE 8.3.4.2 THAT STATES FIRE DOOR ASSEMBLIES FOR VERTICAL SHAFTS (INCLUDING STAIRWAYS, EXITS, AND REFUSE CHUTES) ARE RATED AND REQUIRED FOR 1 HOUR.

Notes: ALL APARTMENTS AND BASEMENT

Comments:

STATE OF MAINE

DISTRICT COURT
Location: Portland
Docket No.

CITY OF PORTLAND and body politic and
Corporate, located in the County of
Cumberland and State of Maine,

Plaintiff,

v.

Rocco Genovese
Defendant


**FIRE PREVENTION AND PROTECTION
CODE VIOLATION**

(M.R. CIV. P. 80H AND 80k)

SUMMONS NUMBER: 353699

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 07/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 07/11/2016.

Dated: 4/25/16



Adam R. Lee, Esq. Bar No. 4143
Associate Corporation Counsel
City of Portland
389 Congress St
Portland, ME 04101
207-874-8480