

CITY OF PORTLAND
Fire Department
380 Congress Street
Portland, Maine 04101

Fire Inspection Violations

Business 12 APARTMENTS	Location 0193 CONGRESS ST	Number 66505-0-0	Inspection Type FP Routine Inspection
Owner/Manager H A T LLC	CBL 013 M023001	Inspector ROBERT V PINDER Shift: 001 Unit: E1	

Code	Type	Location	Inspection Date	Target Compliance	Actual Compliance	
1	4.5.4*	Fire alarms shall be provided to wa	7/11/05	8/18/05	8/24/07	
2	6-2.3.2.4	Hole in wall needs repair	2nd and 3rd floor halls	7/11/05	8/18/05	8/24/07
3	6-2.3.2.4	Hole in wall needs repair	3rd floor hall	7/11/05	8/18/05	8/24/07
5	NFPA70	Incorrect fuse size	in basement	7/11/05	8/18/05	8/24/07
6	NFPA18-1.	Smoke detector needs repair	Laundry room	7/11/05	8/18/05	8/24/07
7	OCC3.4.4	Smoke detector required	3rd floor hallway	7/11/05	8/18/05	8/24/07
8	101-5-21	Fire Doors Required	all apartments	7/11/05	8/18/05	8/24/07
9	19-2.9	Emergency lights installed	all hallways	7/11/05	8/18/05	7/11/05
10	101-31.2.1	Exit signs maintained	all exits	7/11/05	8/18/05	
11	31.3.4.2.1	Manual pull stations required	hallways	7/11/05	8/18/05	8/24/07