

**CITY OF PORTLAND**  
**Fire Department**  
 380 Congress Street  
 Portland, Maine 04101

**Fire Inspection Violations**

<b>Business</b> 12 APARTMENTS	<b>Location</b> 0193 CONGRESS ST	<b>Number</b> 66505-0-0	<b>Inspection Type</b> FP Re-Inspection
<b>Owner/Manager</b> H A T LLC	<b>CBL</b> 013 M023001	<b>Inspector</b> ROBERT V PINDER Shift: 001 Unit: E1	

<b>Code</b>	<b>Type</b>	<b>Location</b>	<b>Inspection Date</b>	<b>Target Compliance</b>	<b>Actual Compliance</b>
1	<b>NFPA1-7-5</b>	Suppression system needs service	Sprinkler needs to be tested yearly	8/18/05	9/19/05
2	<b>NFPA13</b>	P.I.V. not locked	No Spare Sprinkler heads	8/18/05	9/19/05
3	<b>NFPA13</b>	P.I.V. not locked	Water feed must be equal to pipe size	8/18/05	9/19/05