RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/12/14

NOTE: WILL NEED TO HAVE ELECTRICIAN INSTALL 110 SMOKES IN THE 3RD FLOOR HALLWAY

2ND FLOOR; 3RD FLOOR MIRRORS THIS FLOOR