

Portland, Maine



Yes. Life's good here.

Jerome F. LaMoria  
Fire Chief, Fire Department

Portland Fire Department  
Fire Prevention Bureau  
380 Congress St  
Portland, ME 04101

June 11, 2015

Andrew J Roy &  
Coleen Roy JTS  
18 Jackson St  
Portland, ME 04103

#### NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at 86 Quebec St on June 09, 2015 revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at [www.portlandmaine.gov](http://www.portlandmaine.gov).

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department  
Fire Prevention Bureau

**CITY OF PORTLAND  
PORTLAND FIRE DEPARTMENT**

380 Congress Street  
Portland, Maine 04101

**Inspection Violations**

<b>Owner/Manager</b> ROY ANDREW J &		<b>Inspector</b> Curtis Magnuson	<b>Inspection Date</b> 6/9/2015
<b>Location</b> 86 QUEBEC ST	<b>CBL</b> 014 A002001	<b>Status</b> Failed	<b>Inspection Type</b> Fire Company-FP Routine Inspec

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 9.002

**Violation:** NFPA 80- ANNEX D.4 1-HOUR FIRE DOORS ASSEMBLIES REQ; Listings are provided for floor fire door assemblies that are installed in fire-rated floor-ceiling or roof-ceiling assemblies that have been tested in accordance with the methods described in NFPA 288. The listing indicates the fire-rated assembly and the hourly rating (3 hours, 2 hours, 1.5 hours, 1 hour, .75 hours) for which the door can be permitted to be used so that access to the space above the ceiling or to the floor above can be provided without adversely affecting the fire resistance rating of the entire assembly. The listing provides limitations on the maximum size of an individual door opening and the total area of all door openings permitted for each 100 square feet of floor or ceiling.

**Notes:**

2) 73.10

**Violation:** NFPA 101-7.2.4.3.1 FIRE BARRIER REQUIRES MAINTENANCE; Fire barriers separating buildings or areas between which there are horizontal exits shall have a minimum 2-hour fire resistance rating, unless otherwise provided in 7.2.4.4.1, and shall provide a separation that is continuous to the finished grounded level.

**Notes:** REAR STAIRWELL HOLES

3) 73.15

**Violation:** NFPA 31.3.1.1.1 VERTICAL OPENINGS NOT FIRE RATED; VERTICAL OPENINGS SHALL BE ENCLOSED OR PROTECTED IN ACCORDANCE WITH SECTION 8.6.

**Notes:** REAR STAIRWELL 2ND FLOOR CEILING

4) 80.46

**Violation:** NFPA 101- 7.2.1.8.1 FIRE DOORS MUST BE SELF- OR AUTO-CLOSING; A door leaf normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2, unless otherwise permitted by 7.2.1.8.3.

**Notes:** ALL APARTMENT DOORS AND BASEMENT DOOR

5) 80.80

**Violation:** NFPA 101- 7.5.1.1.1 SECOND EXIT REQUIRED; Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to no less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4.

**Notes:** THIRD FLOOR APARTMENT ONLY 1 STAIRWELL SERVICING UNIT

**CITY OF PORTLAND  
PORTLAND FIRE DEPARTMENT**

380 Congress Street  
Portland, Maine 04101

**Inspection Violations**

<b>Owner/Manager</b> ROY ANDREW J &		<b>Inspector</b> Curtis Magnuson	<b>Inspection Date</b> 6/9/2015
<b>Location</b> 86 QUEBEC ST	<b>CBL</b> 014 A002001	<b>Status</b> Failed	<b>Inspection Type</b> Fire Company-FP Routine Inspec

6) 91.10

**Violation:** NFPA 70- ARTICLE 110 B CERTIFY ELECTRICAL SYSTEM; LISTED OR LABELED EQUIPMENT SHALL BE INSTALLED AND USED IN ACCORDANCE WITH ANY INSTRUCTIONS INCLUDED IN THE LISTING OR LABELING.

**Notes:** OPEN JUNCTION BOXES THROUGHOUT BUILDING. ALSO ELECTRICAL WIRE ISSUE IN REAR STAIRWELL CLOSET SECOND FLOOR.

7) 3.011

**Violation:** NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED; THE AREAS DESCRIBED IN TABLE 31.3.2.1.1 SHALL BE PROTECTED AS INDICATED:  
BOILER AND FUEL-FIRED HEATER ROOMS SERVING MORE THAN A SINGLE DWELLING UNIT (MINIMUM SEPARATION/PROTECTION IS 1 HOUR OR SPRINKLERS)

**Notes:** OVER GAS HEATERS IN THE BASEMENT

8) 9.006

**Violation:** NFPA 101- 7.2.1.8.1 FIRE DOOR(S) MUST SELF-CLOSE; A door leaf normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2, unless otherwise permitted by 7.2.1.8.3.

**Notes:**

9) 7.011

**Violation:** INSIDE STORAGE NOT ORDERLY; INSIDE STORAGE NOT ORDERLY

**Notes:** BASEMENT

10) 7.001

**Violation:** NFPA 54- 9.6.4 UTILITY DISCONNECTS BLOCKED; Each appliance connected to a piping system shall have an accessible, approved manual shutoff valve with a nondisplaceable valve member, or a listed gas convenience outlet. Appliance shutoff valves and convenience outlets shall serve a single appliance only and shall be installed in accordance with 9.6.4.1.

**Notes:** NOTHING ALLOWED WITHIN 36" OF ELECTRICAL PANELS

11) 55.040

Exterior

**Violation:** NFPA 101- 31.3.1.1 VERTICAL OPENING VIOLATIONS; VERTICAL OPENINGS SHALL COMPLY WITH 31.3.1.1.1 THROUGH 31.3.1.2.

**Notes:** HOLE IN TRIM ALONG SOFFIT ON LEFT SIDE OF THE BUILDING

**Comments:**

STATE OF MAINE

DISTRICT COURT

Location: Portland

Docket No.

CITY OF PORTLAND and body politic and  
Corporate, located in the County of  
Cumberland and State of Maine,

Plaintiff,

**FIRE PREVENTION AND PROTECTION  
CODE VIOLATION**

**(M.R. CIV. P. 80H AND 80k)**

v.


Andrew Roy & Coleen Roy  
Defendant

SUMMONS NUMBER: 353800

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on July 13, 2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at [meservev@portlandmaine.gov](mailto:meservev@portlandmaine.gov) to set up an in-person meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on July 13, 2015.

Dated:

6/17/15



---

Adam R. Lee, Esq. Bar No. 4143  
Associate Corporation Council  
City of Portland  
389 Congress St  
Portland, ME 04101  
207-874-8480