

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager Hollyday Multi Llc		Inspector	Inspection Date 7/13/1993
Locatation 86 Quebec St	CBL 014 A002001	Status Green 0-4 Violations	Inspection Type Housing-Housing Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.3	EXT				
Violation: Exterior windows, doors and skylights					
Notes: LEFT FRONT CELLAR WINDOW MISSING GLASS					
2) 6-108.3	INT				
Violation: Exterior windows, doors and skylights					
Notes: 3RD FL APT BATHROOM WINDOW INOPERATIVE					
3) 6-108.3	INT				
Violation: Exterior windows, doors and skylights					
Notes: 3RD FL APT BEDROOM WINDOW MISSING STORM					
4) 6-108.3	INT				
Violation: Exterior windows, doors and skylights					
Notes: 3RD FL; APT #3 BATHROOM LACKS VENTILATION					
5) 6-113.5	INT				
Violation: Maintenance of lighting fixtures					
Notes: OVERALL HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT					

Comments: Letter Info: 7/13/93: LOD LETTER, 7/21/95: STND 1ST W/SUGG