



... Fire Protection by Computer Design

High Tech Fire Protection
PO Box 156
Minot, ME 04258
(207) 998-2551

Job Name : Second Floor Calc.
Building : 42 Lafayette Street
Location : 42 Lafayette Street
System : NFPA 13R
Contract : NA
Data File : Second Floor Calc.wxf

HYDRAULIC DESIGN INFORMATION SHEET

Name - Second Floor Calc. Date - 08/31/2017
Location - 42 Lafayette Street
Building - 42 Lafayette Street System No. - NFPA 13R
Contractor - High Tech Fire Protection Contract No. - NA
Calculated By - Jeremy A Foss Drawing No. - FP-1.1
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-0"
OCCUPANCY - Residential - Apartment

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 14 Gpm System Type
Listed Pres. at Start Point - 10.2 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16' x 16' () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make Reliable Model FlRes 44
I Elevation at Highest Outlet - 26 Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 57 Psi Required 44 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 06/09/2017 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 51 Elev.
R Residual (Psi) - 48 Other Well
Flow (Gpm) - 838 Proof Flow Gpm
S Elevation - -6

P Location: Test Hydrant Located on Congress Street - 800' from Site

P
L Source of Information: Portland Water District
Y


Water Supply Curve (C)

High Tech Fire Protection
Second Floor Calc.

Page 2
Date 08/31/2017

City Water Supply:
C1 - Static Pressure : 51
C2 - Residual Pressure: 48
C2 - Residual Flow : 838

Demand:
D1 - Elevation : 13.859
D2 - System Flow : 56.883
D2 - System Pressure : 43.954
Hose (Demand) : _____
D3 - System Demand : 56.883
Safety Margin : 7.025



Fittings Used Summary

High Tech Fire Protection
Second Floor Calc.

Page 3
Date 08/31/2017

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
N *	CPVC 90'EII Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0	
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
V	90' EII Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0	
Zik	Wilkins 950XL	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
Second Floor Calc.

Page 4
Date 08/31/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
401	26.0	4.4	10.2	na	14.05	0.05	196	10.2
402	26.0	4.4	10.5	na	14.26	0.05	196	10.2
403	26.0	4.4	10.67	na	14.37	0.05	196	10.2
B1	26.0		10.88	na				
404	26.0	4.4	10.42	na	14.2	0.05	196	10.2
B2	26.0		10.96	na				
B3	26.0		14.3	na				
B4	26.0		19.9	na				
WF1	6.0		29.21	na				
TOR	6.0		30.22	na				
BOR	1.0		38.94	na				
H1	0.0		41.32	na				
H2	-3.0		42.65	na				
H3	-6.0		43.95	na				
TEST	-6.0		43.95	na				

The maximum velocity is 9.1 and it occurs in the pipe between nodes B2 and B3

Final Calculations - Hazen-Williams

High Tech Fire Protection
Second Floor Calc.

Page 5
Date 08/31/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
401 to 402	14.05	1.101 150.0	1N	7.0 0.0	1.400 7.000	10.200 0.0			K Factor = 4.40	
402 to B1	14.05	0.0355		0.0	8.400	0.298			Vel = 4.73	
402 to B1	14.26	1.394 150.0		0.0 0.0	9.300 0.0	10.498 0.0			K Factor = 4.40	
	28.31	0.0410		0.0	9.300	0.381			Vel = 5.95	
	0.0 28.31					10.879			K Factor = 8.58	
403 to B1	14.37	1.101 150.0	1O	5.0 0.0	0.700 5.000	10.668 0.0			K Factor = 4.40	
B1 to B2	14.37	0.0370		0.0	5.700	0.211			Vel = 4.84	
B1 to B2	28.31	1.394 150.0		0.0 0.0	0.900 0.0	10.879 0.0				
	42.68	0.0878		0.0	0.900	0.079			Vel = 8.97	
	0.0 42.68					10.958			K Factor = 12.89	
404 to B2	14.20	1.101 150.0	1O	5.0 0.0	9.900 5.000	10.420 0.0			K Factor = 4.40	
B2 to B3	14.2	0.0361		0.0	14.900	0.538			Vel = 4.79	
B2 to B3	42.68	1.598 150.0	1N	9.0 0.0	34.600 9.000	10.958 0.0				
	56.88	0.0767		0.0	43.600	3.343			Vel = 9.10	
B3 to B4	0.0	1.682 120.0	1Fsp 1G	0.0 1.237	6.500 22.274	14.301 3.000			* Fixed loss = 3	
	56.88	0.0903	1S 1T	11.137 9.9	28.774	2.598			Vel = 8.21	
B4 to WF1	0.0	2.157 120.0	1V	4.307 0.0	20.000 4.307	19.899 8.662				
WF1 to TOR	56.88	0.0269		0.0	24.307	0.653			Vel = 4.99	
WF1 to TOR	0.0	2.157 120.0	1E 1T	6.153 12.307	18.900 18.460	29.214 0.0				
	56.88	0.0269		0.0	37.360	1.005			Vel = 4.99	
TOR to BOR	0.0	2.157 120.0	1Zik 1E	0.0 6.153	5.000 6.153	30.219 8.421			* Fixed loss = 6.255	
	56.88	0.0268		0.0	11.153	0.299			Vel = 4.99	
BOR to H1	0.0	1.917 150.0	1G 1T	1.047 10.47	50.000 11.517	38.939 0.433				
	56.88	0.0316		0.0	61.517	1.944			Vel = 6.32	
H1 to H2	0.0	8.23 100.0	1T	29.011 0.0	525.000 29.010	41.316 1.299				
	56.88	0.0001		0.0	554.010	0.031			Vel = 0.34	
H2 to H3	0.0	12.24 100.0	1T	48.362 0.0	275.000 48.362	42.646 1.299				
	56.88	0.0		0.0	323.362	0.003			Vel = 0.16	
H3 to TEST	0.0	6.14 100.0	1E 1G	10.608 2.273	15.000 12.881	43.948 0.0				
	56.88	0.0002		0.0	27.881	0.006			Vel = 0.62	

Final Calculations - Hazen-Williams

High Tech Fire Protection
Second Floor Calc.

Page 6
Date 08/31/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 56.88					43.954		K Factor =	8.58