



February 16, 2016

At Home Properties Llc

100 High Point Dr # 608

Hartsdale, NY 10530

CBL: 014 B007001

Located at 127 CONGRESS ST

#### NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at [www.portlandmaine.gov](http://www.portlandmaine.gov).

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

A handwritten signature in cursive script that reads "Capt. Petrucelli".

Portland Fire Department

Fire Prevention Bureau

**CITY OF PORTLAND  
PORTLAND FIRE DEPARTMENT**

380 Congress Street  
Portland, Maine 04101

**Inspection Violations**

<b>Owner/Manager</b> At Home Properties Llc		<b>Inspector</b> David Petruccelli	<b>Inspection Date</b> 1/29/2016
<b>Location</b> 127 CONGRESS ST	<b>CBL</b> 014 B007001	<b>Status</b> Failed	<b>Inspection Type</b> Fire Prevention-FP Routine Inspe

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
-------------	----------------	--------------	-----------------	-------------	------------------------

1) 73.05

**Violation:** NFPA 101- 7.2.1.15.8 FIRE DOOR ASSEMBLY REQ REPAIR; DOOR OPENINGS NOT IN PROPER OPERATING CONDITION SHALL BE REPAIRED OR REPLACED WITHOUT DELAY.

**Notes:** SELF CLOSERS SHALL BE ADJUSTED PROPERLY

2) 80.37

**Violation:** NFPA 101- 8.3.4.2 60 MINUTE FIRE DOOR REQUIRED; REFER TO NFPA 101- TABLE 8.3.4.2 THAT STATES FIRE DOOR ASSEMBLIES FOR VERTICAL SHAFTS (INCLUDING STAIRWAYS, EXITS, AND REFUSE CHUTES) ARE RATED AND REQUIRED FOR 1 HOUR.

**Notes:** 2ND AND 3RD FLOORS, FRONT AND REAR DOORS TO APARTMENTS

**Comments:**

STATE OF MAINE

DISTRICT COURT  
Location: Portland  
Docket No.

CITY OF PORTLAND and body politic and  
Corporate, located in the County of  
Cumberland and State of Maine,

Plaintiff,

**FIRE PREVENTION AND PROTECTION  
CODE VIOLATION**

**(M.R. CIV. P. 80H AND 80k)**

v.


At Home Properties LLC  
Defendant

SUMMONS NUMBER: 353672

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 04/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at [meservev@portlandmaine.gov](mailto:meservev@portlandmaine.gov) to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 04/11/2016.

Dated:

2/25/16



---

Adam R. Lee, Esq. Bar No. 4143  
Associate Corporation Counsel  
City of Portland  
389 Congress St  
Portland, ME 04101  
207-874-8480